


Synchronising Device SYR 2

Description

SYR 2



**Synchronisation between mains, generators
or transformers**

**Protective functions according to ANSI/IEEE C37.2:
12, 13, 14, 25, 27, 59, 81, 90**

Synchronising Device SYR 2

Description

LIST OF CONTENTS

1	General Remarks	6
2	Safety Information	6
3	Measurement	7
3.1	Voltage Measurement	7
3.2	Frequency Measurement	7
3.3	3-phased mains (with or without Neutral Conductor)	7
3.4	1-phased Grids	7
3.5	Behaviour at low Voltages	7
4	Installation	8
4.1	Mechanical Installation	8
4.2	Electrical Installation	8
4.2.1	Connection Diagram	8
4.3	Commissioning	9
4.3.1	Basic Settings	9
5	Operation	10
5.1	Overview of the Control Elements	10
5.1.1	Buttons	10
5.1.2	DIL Switches	11
5.1.3	LEDs	11
5.1.4	Graphic Display	11
5.1.5	USB Interface / Driver Install	12
5.2	Display View	12
5.2.1	Main Screen	12
5.2.1.1	Fault message display	12
5.2.2	Synchronisation	13
5.2.3	Menu Structure	14
5.2.3.1	Actual fault	16
5.2.3.2	Measuring Values	16
5.2.3.3	Fault Messages	17
5.2.3.4	Info	18
6	Configuration of the Device	19
6.1	Transformer settings	19
6.2	Nominal Values of the Plant	19
6.3	Display Format	20
6.4	Configuration via GV-2	20

Synchronising Device SYR 2

Description

6.5	Configuration at the Device	20
6.5.1	Protection of Input with PIN	20
6.6	Parameter Setting	21
6.6.1	Selection of Groups and Parameters	21
6.6.2	Entering of a Value	22
6.6.3	Setting the Fault Message Coding	23
6.7	Setting of Time and Date	24
6.7.1	Via GV-2	24
6.7.2	Manually Setting of Time	25
6.8	Language Selection and Switching	25
7	Operation	26
7.1	Operating Principle	26
7.2	Parallel Switching Points (PSP)	26
7.3	Operating Modes	26
7.3.1	Mains parallel Mode	27
7.3.2	Synchronisation Mode	27
7.3.3	Isolated operation Mode	27
7.4	Synchronisation	27
7.4.1	Synchronisation clearance	27
7.4.2	Syn Pulse	27
7.4.3	Switching-on clearance	28
7.4.3.1	Switching-on Voltage	28
7.4.3.2	Switching-on Frequency	28
7.4.4	Monitoring Functions	29
7.4.4.1	Clearance Monitoring	29
7.4.4.2	Monitoring of Synchronisation Pulse	29
7.4.4.3	Delta-f Clearance	29
7.4.5	Isolated Operation	29
7.5	Usage as Locking Relay	30
7.6	Switching onto Dead Bus-Bar	30
7.7	Synchronisation Pulse as permanent Contact	31
7.8	Limit Values	31
7.8.1	Behaviour of the Limit Values	31
7.8.2	Triggering of Limit Values	31
7.8.3	Manually / Automatically Reset	32
7.8.4	Disable limit values	32
7.8.5	Central Fault	32
7.8.6	Central Fault 1+2	33
7.8.7	Display First Error	33
7.8.8	SYN-preventing Limit Value	33
7.8.9	Operating Mode depended Release (only generator Limit Values)	33
7.9	Limit Value Settings	34
7.9.1	Rotary Field Monitoring (Mains and/or Generator)	34
7.9.2	Monitoring of Angle Error (Mains and/or Generator)	34
7.9.3	Voltage Triggering – Under-/Overvoltage (Mains and/or Generator)	35
7.9.4	Voltage Asymmetry Triggering (Mains and/or Generator)	35
7.9.5	Deviation of Voltage Mean Value (Mains and/or Generator)	36
7.9.6	Frequency Triggering Under-/Overfrequency (Mains and/or Generator)	36

Synchronising Device SYR 2

Description

7.9.7	Vector Shift Triggering (Mains)	37
7.9.8	Delta f to Delta t (ROCOF) (Mains)	37
7.9.9	Slip	37
7.10	Trigger Memory	38
7.10.1	Reading out the Trigger Memory	38
7.11	Programmable Switching Points	39
8	PID-T1 Controller	40
8.1	Controller Ramps	40
8.2	Dead Zone	40
8.3	Clearance Delay	40
8.4	Controller Parameters	41
9	Pulse Controller	42
9.1	PFM (Pulse Frequency Modulation)	42
9.1.1	Controller Parameters	43
9.2	PWM (Pulse Width Modulation)	43
9.2.1	Controller Parameters	44
9.3	Dead Zone	44
9.4	Release Delay	44
10	Electronic Potentiometer	45
10.1	Parameters	45
11	Inputs	46
11.1	Digital Inputs	46
11.1.1	Monitoring of the Relay- (Contactor-) Acknowledgement	47
12	Outputs	48
12.1	Digital Outputs	48
12.2	Analogue Outputs (optionally)	53
13	Logic Functions	55
13.1	Output Logic Function on Digital Input Function	55
13.2	AND – Gate (1)	56
13.3	OR – Gate (2)	56
13.4	Exclusive OR – Gate (3)	56
13.5	AND-Not – Gate (4)	56
13.6	OR-Not – Gate (5)	56
13.7	Exklusiv Nicht-ODER – Gatter (6)	56
13.8	Timer pick up delayed	57
13.9	Timer abfallverzögert	57

Synchronising Device SYR 2

Description

13.10	Fault Message Assignment	57
13.11	Locking Functions and Auto Reset	57
14	Technical Data	58
14.1	Triggering Values	58
Annex 1	Parameter Groups	59
Annex 1.1	Configuration (Konfig. / Config – Group 1)	59
Annex 1.2	Limit Values (Grenzwerte / Limits – Group 4)	60
Annex 1.3	Analogue Outputs	62
Annex 1.4	Digital Outputs (Digi. Ausg. / OUT – Group 6)	62
Annex 1.5	Digital Inputs (Digi. Eing. / IN – Group 7)	63
Annex 1.6	Logic Functions (Logik – Group 10)	63
Annex 1.7	Syn (SYN – Group 11)	64
Annex 1.8	PID-T1-, Pulse Controller and Electronic Potentiometers (Regler–Group 12)	66

Synchronising Device SYR 2

Description

1 General Remarks

The synchroniser relay SYR2 adjusts voltage and frequency of a generator to the mains, in order to connect it to the mains at a minimum of frequency and voltage deviation, and with identical phasing. Depending on its configuration, the SYR2 is monitoring sense of rotation, voltage difference and asymmetry.

Voltage measurement is done as 2-, 3- or 4- (3 + N) conductors measurement, according to the respectively preset parameterisation. Frequency measurement is basically carried out on L1 and L2. In isolated operation, the desired frequency and voltage are internally set by the device.

The SYR2 allows the interconnection of up to four parallel switching points. Separate parameters can be set for each switching point.

The SYR2 enfolds the following functions [according to ANSI/IEEE C37.2]:

- Overspeed Device/Protection [12]
- Synchronous-Speed Device [13]
- Underspeed Device [14]
- Synchronizing or synchronism-check device [25]
- Undervoltage [27]
- Overvoltage [59]
- Monitoring of frequency [81]
- Controller (voltage / frequency) [90]

For parameterisation of the SYR2 it is recommended to use of the supplied parameterisation software Geräteverwaltung 2, which is also available on our website (*download of the current version*).



Note: Depending on the version of the used parameterisation software (Geräteverwaltung 2) the used images of this document may differ from the actually appearance within the software.

2 Safety Information



Caution! The following safety and installation instructions must be observed when handling the device:

- Installation and commissioning only by trained professionals.
- The user is responsible for checking the correct configuration of the SYR2 before commissioning or maintaining the device.
- Maximum values given in this description must not be exceeded.
- The device must be disconnected from the mains during maintenance and installation.

Symbols shown in this description have the following meaning:



The Caution symbol indicates possible injury or life hazards.



Explanatory text or hint on special features at the handling or behaviour of the device.

Synchronising Device SYR 2

Description

3 Measurement

3.1 Voltage Measurement

The voltage measurement is a true root mean square value measurement. It operates up to a neutral point voltage lower limit of approximately 10 V (L-N). As soon as a measuring voltage is detected, the LED of the respective phase lights up. The SYR2 can be deployed in mains of 57/100 V up to 230/400 V. The accuracy of the voltage measurement is better than 0.2 % of the end value (280/480 V).

The six string voltages are measured simultaneously with 32 samples per period.



Note: As long as no frequency is measured, the sampling of the voltage measurement operates with the adjusted nominal frequency.

3.2 Frequency Measurement

The frequencies of the three grid voltages as well as the frequencies of two generator voltages are recorded and evaluated separately. The frequency measurement begins with a phase voltage of approx. 10 V. The accuracy at absolute values is better than 0.01 Cy.

3.3 3-phased mains (with or without Neutral Conductor)

Measuring with or without neutral point may be selected by the choice of the measurement method. At measuring without neutral point, it is not necessary to connect a neutral conductor. Due to a special internal wiring of the terminals, in a 3-wire + N – system the loss of the neutral conductor can be detected and indicated in form of a voltage asymmetry or undervoltage Lx.

3.4 1-phased Grids

If the SYR2 is set to 2-conductor operation, the measurement and monitoring is only carried out between L1 and N. The limit values for angle error, rotary field monitoring, mean value and asymmetry are internally deactivated, vector shift must be adjusted.

3.5 Behaviour at low Voltages

Below a measuring voltage of approx. 20 V, the accuracy of the voltage measurement and the angle measurement decreases. The measuring voltage lower limit is reached at approx. 10 V. Then for frequency and voltage 0 is displayed.

Synchronising Device SYR 2

Description

4 Installation

Assembly and commissioning only by trained professionals, Connection in compliance with VDE 0160.

4.1 Mechanical Installation

The SYR2 is designated for a mounting on a 35 mm top-hat rail, according to DIN EN 60715. The installation width is approx. 100 mm.

4.2 Electrical Installation




Assembly and commissioning only by trained professionals.

Selecting the cables and the electrical connection of the device, the regulations of the VDE 0100 "Regulations for the Setting up of Power Installations with nominal Values below 1000 V", VDE "Equipment of Power Installations with Electrical Components" resp. the respective national / local regulations must be observed.

The electrical connection has to be carried out only by trained professional staff (VDE 1000 T. 10).

The device must be disconnected from the mains during maintenance and installation work.

4.2.1 Connection Diagram



Synchronising Device SYR 2

Description

4.3 Commissioning

For putting the SYR2 into operation, it is to connect as per connection diagram (see *chap. 4.2.1*). In the following, parameterisation must be done. The device is calibrated at the factory and pre-set with factory settings.

4.3.1 Basic Settings

On commissioning, the settings of the converter ratios for voltage as well as the nominal voltages are to adapt in compliance with the plant parameters.

At the first start-up, settings must be made to adapt the SYR2 to the respective plant. This includes the nominal voltage according to the plant parameters as well as the converter ratios for the voltage measurement. The settings can be done by the supplied, respectively for downloading on our homepage available parameterisation software 'Geräteverwaltung 2 GV-2', alternatively inputs are possible directly at the device (see *chap. 6.5 -*).


The procedure for parameter input on the device is described in detail in chapter 6 - Configuration of the Device.

Synchronising Device SYR 2

Description

5 Operation


5.1 Overview of the Control Elements



Note: The control elements, DIL switches and PC-Interface (USB interface) are only accessible, when the front lid of the SYR2 is removed. It is unconditional to avoid to touch other than the here listed elements. After completion of the intended activities, the cover must be replaced.

5.1.1 Buttons

For direct access to the operation of the device, the SYR2 has two buttons (*figured below*). In connection with the DIL switch (see *chap. 5.1.2*) and the graphic display, almost all relevant settings can be performed directly at the device. The following functions are assigned to the buttons:



UP button

- Scrolling through various menus
- Increasing of values in the parameter setting (see *chap. 5.2 – display view*)
- Deleting Deleting of stored trigger values (see *chap. 7.10 - Trigger Memory*)

Enter button

- Enter a menu item
- Exit a (sub-)menu item (press & hold 2s)
- Confirming an entry
- In operation: scrolling through the various main screens
- In main screen: performing a limit value reset (press & hold 2s, see *chap. 7.8.3*)


Synchronising Device SYR 2

Description



Note: The functions of the SYR2 buttons listed above are not to be seen as a complete list of all functions. Further details and notes on functions of the buttons of the SYR2 are described in the respective chapter of this document, which refers to the operation of the device by means of the buttons.

5.1.2 DIL Switches



The DIL Switches have the following functions:

- | | | |
|----------|-----|--|
| S1: | OFF | - automatic fault message reset acc. to parameterisation |
| | ON | - STM auto reset disabled; reset by digital input or reset button (press & hold Enter button 2s) |
| S2: | ON | - editing of parameters |
| S3: | ON | - language switching |
| S4: | ON | - enforce delta-f clearance |
| S2 + S4: | ON | - setting the device clock |

5.1.3 LEDs

The LEDs have the following functions:

- LED U_B : The LED is on (green), when voltage is detected at all configured phases of the mains.
- LED U_G : The LED is on (green), when voltage is detected at all configured phases of the generator.
- LED Δ_U : The LED is on (green), when the difference of voltage between mains and generator ranges within the set limit values at released synchronisation.
- LED f_B : The LED is on (green), when frequency is detected at all configured phases of the mains.
- LED f_G : The LED is on (green), when frequency is detected at all configured phases of the generator.
- LED Δ_f : The LED is on (green), when the frequency between mains and generator ranges within the set limit values at released synchronisation.
- LED DI1 ... DI3: The LEDs represent the corresponding digital input. If the input is activated (bridged to KL 1), the associated LED is on (green). The parameterization of the input after quiescent or working current is irrelevant here.
- LED DO1 ... DO6: The LEDs represent the corresponding relay output. If the relay output is activated (relay energised), the associated LED is on (green). The parameterization of the input after quiescent or working current is irrelevant here.

5.1.4 Graphic Display

The device status is output via a backlit graphic display with a resolution of 132 x 32 pixels. In connection with the DIL switches and the Buttons almost all relevant settings can be performed directly at the device. All relevant (measuring-) data are as well shown on the graphic display.


Synchronising Device SYR 2

Description

5.1.5 USB Interface / Driver Install

The SYR2 is equipped with an USB interface (mini-USB), which allows parameterisation of the device. To ensure the correct function, the USB driver file 'lpc_driver_setup.exe' must be installed before the first use (file can be found on the delivery included installation medium as well as, after installation of the 'Device Management', in the program folder of GV-2). PCs with the operating system Windows XP or later are supported.


Connect the SYR2 to the designated PC system using an USB cable (parameterisation cable USB A: USB Mini B) and switch on the auxiliary voltage of the SYR2.



Open the folder 'driver' on the installation medium or from the program folder of the parameterisation software 'Geräteverwaltung 2' (GV-2) and start the program 'lpc_driver_setup.exe' (figured left). Follow the installation instructions of the program (enter the administrator password if necessary)

After successful completion of the installation process, the interface 'LPC USB VComPort' should be listed in the Windows device manager (figured right). The parameterisation software 'Geräteverwaltung 2' now can be used with the SYR2.

During regular operation the USB cable should be disconnected.



5.2 Display View

5.2.1 Main Screen


The main display shows the relative voltage values of the two systems as bars, as well as the slip frequency between the systems on the left side.



With the Enter button you can switch between different views with all relative and absolute measured values.

Pressing the UP button, the menu will be entered.

5.2.1.1 Fault message display



The fault message display indicates the latest active fault message. If no fault message is active, the field is displayed as a dark field.

Synchronising Device SYR 2

Description


Text in fault message field	Fault message
UB < X%	Voltage mains lesser limit
UB > X%	Voltage mains higher limit
UG < X%	Voltage generator lesser limit
UG > X%	Voltage generator higher limit
fB < X%	Frequency mains lesser limit
fB > X%	Frequency mains higher limit
fG < X%	Frequency generator lesser limit
fG > X%	Frequency generator higher limit
VB > X°	Vector jump mains
dfB > X	ROCOF mains
WinkelB >	Angle mains higher limit
WinkelG >	Angle generator higher limit
dUB > X%	Asymmetry mains higher limit
dUG > X%	Asymmetry generator higher limit
Drehf.B	Mains rotation failure
Drehf.G	Generator rotation failure
Uquali.B	Voltage quality mains out of limits
Umitt. B	Average mains out of limits
Umitt. G	Average generator out of limits
Schlupf	Slip frequency out of limits
T Syn	Syn-impulse-monitoring tripped
Frg nOK	Release-monitoring tripped

5.2.2 Synchronisation

With the beginning synchronisation, the main screen of the SYR2 changes automatically into the hereby relevant display view.

The upper axis shows above the voltage difference ΔU and below the frequency Δf . The arrow shows the respective largest deviation (L1, L2 or L3). The two inner marking lines characterise the maximum permissible deviation, ΔU_{max} and Δf_{max} , of the respective selected parallel switching point. The axis is scaled according to the set limit values.

The lower axis shows the phase angle between U_s and U_g (mains and generator).




Synchronising Device SYR 2

Description

5.2.3 Menu Structure


The menu can be called up from the main screen using the UP button. Pressing the Enter button then activates the respective submenu.



(Onwards at the next page)

Synchronising Device SYR 2


Description



Synchronising Device SYR 2

Description

(Onwards to display in operating mode, see previous page)



5.2.3.1 Actual fault

The last stored message is shown within the menu 'actual fault' – regardless of whether it is still pending. All measuring values available at the time of the message are retrievable. The UP button can be used to scroll through the measuring values listed below, which were present at the time of the message. Actuating the Enter button switches back to the selection menu.

- Type and time of the last message
- Neutral point voltages of mains and generator absolute and relative
- Conductor voltages of mains and generator absolute and relative
- Frequencies of mains and generator
- Voltage difference mains – generator
- Frequency difference mains – generator

5.2.3.2 Measuring Values

The current measured values are displayed in the menu 'Measuring Values' as described in the following. By means of the parameterisation, the display ranges can be pre-selected or can be set as automatic (factory setting: 0) range switching (see chap. 6.3).

Scrolling is done using the Up button. Actuating the Enter button switches back to the selection menu.

Synchronising Device SYR 2

Description


The following measuring values can be displayed:

- Neutral point voltage of all 3 phases absolute and relative
- Conductor voltage of all 3 Phases absolute and relative
- Frequencies of mains and generator
- Slip (frequency difference mains – generator)
- Voltage differences mains – generator absolute and relative

5.2.3.3 Fault Messages

The last stored messages, regardless of whether these are still pending, are displayed in the 'fault messages' screen. All measured values, which are existing at the time of the respective message, are retrievable. Scrolling through the releases is done with the UP button. Actuating the Enter button changes into the display of individual stored releases. With the Up button one can scroll through the values contained here in. With a long time press (>2s) at the Enter button the display switches back to the previous level.

- Type and time of triggering
- Neutral point voltages of grid and generator absolute and relative
- Conector voltages of grid and generator absolute and relative
- Frequencies of grid and generator
- Voltage difference mains – generator
- Frequency difference mains – generator



Synchronising Device SYR 2

Description

5.2.3.4 Info

In the 'Info' screen, important and service information is displayed:

- Nominal values of the plant
- Setting of the voltage converters
- State of the digital in- and outputs
- Date and time (also setting)
- Firmware- and service information

Synchronising Device SYR 2

Description

6 Configuration of the Device


For a correct adjustment to each individual application, the parameterisation of the device is required. For parameterisation the use of the supplied, respectively for downloading on our Homepage available parameterisation software Geräteverwaltung 2' is recommended. The modification of the most operating settings by direct input at the device is possible as well.

At the first start-up, some settings have to be made in order to adapt the SYR2 to the respective plant. This includes: nominal voltage, nominal frequency, kind of mains and voltage transformer ratios. If these parameters are not correctly adjusted to the plant, the SYR2 will not work properly.

6.1 Transformer settings

The converter ratio for the voltage transformers is specified in the GV-2 (*figured right*) or directly at the device in the ratio of primary voltage to secondary voltage.

A separate value for the converter secondary voltage of the parallel switching point must be set for each parallel switching point. The primary voltage refers to parallel switching point 1 at all parallel switching points.



6.2 Nominal Values of the Plant


The plant nominal values are also entered via GV-2 or directly at the device.



Note:

At 3-wire grid form, the nominal voltage is related to the outer conductor voltage.

At 3-wire + N grid form, the nominal voltage is related to the string voltage.



Synchronising Device SYR 2

Description

6.3 Display Format

The selection of the respective display area depends on the configuration of the plant. Nominal Voltage and setting of the voltage converters must be adapted before commissioning. The measurement range selection is preset to automatically by factory defaults.

The following display areas are provided:

Value	Voltage U
0	automatically
1	0 .. 999,9 V
2	0 .. 9999 V
3	0 .. 99,99 kV
4	0 .. 999,9 kV
5	0 .. 999 kV

6.4 Configuration via GV-2

Values and settings, which are stored on the SYR2 can be read out at any time from the device with a PC system by means of the parameterisation software 'Geräteverwaltung 2' (GV-2). The data can be stored on the PC and printed out for documentation purposes.

6.5 Configuration at the Device

The setting of most values is also possible directly at the device. The menu for editing the parameters is called up in operating mode, while the main screen is shown in the device display - by closing the DIL switch S2 (see chap. 5.1.2). The procedure for the input at the device is described in detail below. The parameter data listed in the section parameter groups (see chap. Annex 1) must be observed.

6.5.1 Protection of Input with PIN

The editing at the device can be protected by a four-digit user defined PIN. With activated PIN protection, an input at the device is only possible, after entering the correct PIN.

The PIN is entered digit by digit from right to left (see also chap. 6.6.2). Using the UP button the respective digit is incremented, with the Enter button the entry of the number will be confirmed and the cursor moves to the next position. If the last digit of the PIN is entered correctly, the display changes into the 'Parameter Setting' menu (see chap. 6.6). If the PIN is entered incorrect, the input line is reset to 0000. The input can be repeated, starting at the last digit (figured above).

```
system protected
please input PIN
PIN : 0000
```

The PIN protection can be set via GV-2 or via the parameter setting at the device (see chap. Annex 1.1).



Note: After the PIN has been successfully entered, the input protection is automatically activated again, if no key has been pressed for more than 10 minutes.

Synchronising Device SYR 2

Description


6.6 Parameter Setting

If the DIL switch S2 is closed (ON), the device display changes to the parameter setting. To exit the parameterisation, the DIL switch S2 must be opened (OFF) again. If the parameterisation is exited without correctly completing of a begun input, the newly set value gets lost and the previous setting remains active. Set values are stored permanently in the flash module of the device. The values are retained even at loss of the voltage supply, a battery based buffering is not required.

The setting values are arranged in parameter groups (see *chap. Annex 1*). Each group contains a number of setting values and, where appropriate, further properties. The following groups are available:

- | | |
|---|----------|
| • Configuration (Konfig. / Config) | Group 1 |
| • Limit values (Grenzwerte / Limits) | Group 4 |
| • Analogue output (Analog. Ausg. / OUT) | Group 5 |
| • Digital output (Digi. Ausg. / OUT) | Group 6 |
| • Digital input (Digi. Eing. / IN) | Group 7 |
| • Logic (Logik) | Group 10 |
| • Synchronisation (SYN) | Group 11 |
| • Controller parameters (Regler) | Group 12 |


6.6.1 Selection of Groups and Parameters




In parameter setting mode (DIL switch S2 closed, input protection PIN inactive) the device display shows the selection of the parameter group (*parameter groups see chap. Annex 1*). Using the Up button (see *chap. 5.1.1*) the respective parameter group, which is intended to be edited, can now be selected.

By actuating the Enter button, the display changes into the menu of the selected group. The subgroup with its parameters to be edited (see *chap. Annex 1*) can be selected herein by means of the scroll function of the Up button (see *chap. 5.1.1 - Buttons*). Shown in the example (*figured below*): Switching from parameter subgroup 6.1.x (Digital Output DO1) to 6.2.x (Digital Output DO2).

```
group : 1
Konfig. / Config
```



The selected subgroup is now called up with the Enter button. The parameter to be changed can be selected in this menu item using the Up button. Shown in the example (*figured below*): Switching from parameter 6.2.1 (Function A2) to parameter 6.2.2 (Switching behaviour A2 – refer to *chap. 12.1 - Digital Outputs*).




Press the Enter key to call up the menu for the editing of the parameter to be changed. After the entry has been made and the change is confirmed (see *chap. 6.6.2*), the display returns to the menu of the current parameter subgroup.

Synchronising Device SYR 2


Description

To move from one menu level to the next higher, that is from the subgroup to the parameter group and from the parameter group) to the group selection, the enter key must be pressed for approx. 1.5 seconds (*figured below*).



6.6.2 Entering of a Value

After selecting the parameter group and -subgroup, as well as the selection of the parameter value, the editing of the value is initiated by pressing the Enter button again. The cursor is at the last position of the value to be edited (*figured right below*).




Repeatedly pressing the Up button will increment the number activated under the cursor (*figured right*). If the highest value is reached in this position, the count returns to the lowest value (9 → 0). The desired setting value is confirmed by actuating the Enter button. The cursor moves to the next digit.

↑ Up button

```
group      : 1
nom. voltage
parameter: 9
value:     00230.1
```


This operation is repeated for all digits of the current value to be changed.



When the last digit (left position) of the value to be changed has been edited and confirmed with the Enter key, a safety query occurs, with which the change of the parameter value must be confirmed. Using the Up button, the current change can be discarded here. The previous setting is retained. Actuating the Enter button (ENT), the entry of the parameter value is accepted and stored in the flash memory of the SYR2. The value is valid immediately after confirmation.

```
value changed

cancel with UP
save with ENT
```



Synchronising Device SYR 2

Description

6.6.3 Setting the Fault Message Coding

The setting of the fault message behaviour is performed bit by bit for the respective limit values. With the selection of parameter 6.x.6 the value in the bottom line of the display is switched to binary number (*figured right*).

Grenzwerte / Limits	
low voltage 1	
parameter : 1	6
1000000000001001	

The bit positions 1, 4, 5, 6, 7, 8, 13, 14, 15 and 16 are adjustable:

Grenzwerte / Limits
low voltage 1
enable
000000000001001

Bit position 1 / enable:

The triggering of the fault message for the respective limit value is activated (1) / not activated (0).

Grenzwerte / Limits
low voltage 1
syn-prevent
100000000001001

Bit position 4 / SYN-preventing

Synchronisation is prevented, if a limit value that is parameterised by this option is triggered.

Grenzwerte / Limits
low voltage 1
disable all
1000100000001001

Bit position 5 / disable all (**only Logic Table [10]**):

The respective limit value can be disabled (1) for the triggering by means of the 'disable all' function.

Grenzwerte / Limits
low voltage 1
disable 3
1000010000001001

Bit position 6 / disable 3:

The respective limit value can be disabled (1) for the triggering by means of the 'disable 3' function.

Grenzwerte / Limits
low voltage 1
disable 2
1000000000001001

Bit position 7 / disable 2:

The respective limit value can be disabled (1) for the triggering by means of the 'disable 2' function.

Grenzwerte / Limits
low voltage 1
disable 1
1000000000001001

Bit position 8 / disable 1:

The respective limit value can be disabled (1) for the triggering by means of the 'disable 1' function.

Grenzwerte / Limits
low voltage 1
ena. at conn. rdy.
1000000000001001

Bit position 9 / enable at connection-readiness:

The respective limit value only is active, if readiness for switching on predominates.

Grenzwerte / Limits
low voltage 1
ena. at mains paral.
1000000000001001

Bit position 10 / enable at mains parallel:

The respective limit value only is active, if the operating type mains parallel mode predominates.

Grenzwerte / Limits
low voltage 1
ena. at isolated op.
1000000000001001

Bit position 11 / enable at isolated operation:

The respective limit value only is active, if the operating type isolated operation predominates.

Grenzwerte / Limits
low voltage 1
ena. at syn
1000000000001001

Bit position 12 / enable at SYN mode:

The respective limit value only is active, if the operating type SYN predominates.

Grenzwerte / Limits
low voltage 1
autoreset
1000000000001001

Bit position 13 / Auto reset:

The auto reset (*see chap. 7.8.3*) is enabled (1) / disabled (0) for the respective limit value.

Synchronising Device SYR 2

Description

Grenzwerte / Limits
low voltage 1
central fault 2
1000000000001001

Bit position 14 / central Fault Message 2:

The fault message triggering for the limit value is additionally - not (0) / carried out (1) under ' Central Fault Message 2' (see chap. 7.8.6)

Grenzwerte / Limits
low voltage 1
central fault 1
1000000000001001

Bit position 15 / central Fault Message 1:

The fault message triggering for the limit value is additionally - not (0) / carried out (1) under ' Central Fault Message 1' (see chap. 7.8.6)

Grenzwerte / Limits
low voltage 1
central fault
1000000000001000

Bit position 16 / central Fault Message (**only Logic Table [10]**):

The fault message triggering for the limit value is - not (0) / carried out (0) under ' Central Fault Message' (see chap. 7.8.5).

6.7 Setting of Time and Date


The real-time clock integrated in the SYR2 operates in 24h format and continues to run for at least 72 hours in case of auxiliary power supply failure. Date and time of the SYR2 can be adjusted in different ways.

1. Using the parameterisation software GV-2.
2. Manually at the device.

6.7.1 Via GV-2

Time and Date are adjustable via GV-2. On this, the time of the used PC system is applied.

The clock of the SYR2 can be set by clicking on 'set clock', or while transferring or reading out the configuration. For this, the option 'adjust clock' must be activated during transmission.




Synchronising Device SYR 2

Description

6.7.2 Manually Setting of Time

The setting of date and time is called up at the device by closing of the DIL switches S2 and S4. Actuating the Enter button, the editing is activated.



Using the Up button now the activated digit is altered. The made setting is confirmed by actuating the Enter button, the cursor changes to the next position of the input area (*figured below – refer chap. 6.6.2 – Entering of a Value*).



The procedure described above must be repeated for all positions of the time and date input.



Note: The day of the week cannot be set manually. The day of the week is set automatically on the base of the set date.

6.8 Language Selection and Switching

Basically the display texts are available at the device in 2 languages. The factory default is German and English. Other languages can be set up at the customer's request and thus made available on the device display by means of the parameterisation software.



Using the device parameterisation it is determined which language is the main language, and whether it is allowed to switch between the languages. The following options are adjustable:

- only language 1 (German)
- only language 2 (English)
- language 1 or language 2 (German / English)
- language 2 or language 1 (English / German)

The switching between the two display languages can alternatively be carried out via the parameterisation software, DIL switch S3 or a parameterised input. If DIL switch S3 or the assigned input is closed, the language is switched according to the parameterization, if the changeover is permitted.

Synchronising Device SYR 2

Description

7 Operation

7.1 Operating Principle


The Synchronising Device SYR2 captures the voltage and frequency of two (separate) alternating current grids. The measurement can be configured either for 2-, 3- or 4- conductors systems. If controlling is approved (SYN-clearance, factory setting DI1), the SYR2 controls the generator voltage and the generator frequency via analogue outputs (PID-T1 controller) as well as pulse controllers (pulse frequency modulated or pulse width modulated, depending on the configuration). The target point of the control is adjustable.

If the clearance input is active (factory setting: DI1) and when generator voltage as well as generator frequency ranges within the predetermined tolerances to the leading mains, a synchron impulse is generated when the grids are in phase balance (see chap. 7.4). In order to compensate delays of the switching elements, the output of synchronous impulse occurs the lead time prior to the calculated time point of synchronisation. The LEDs ΔU and Δf will only be activated, if synchronisation is released.

Using analogue outputs (0(2) ... 10 V / 0(4) ... 20 mA – optionally orderable) measured values can be output to a recorder or manipulated variables can be output to controllers.

The controlling of voltage and/or frequency as well can be performed via the analogue outputs.

7.2 Parallel Switching Points (PSP)



The SYR2 has the ability to synchronise and switch parallel up to four parallel switching points, one after the other to the leading mains (see chap. 11.1). If no parallel switching point is selected, PSP1 is considered active. The voltages to be synchronised must be routed to the SYR2 (via a higher-level controller) according to the selected PSP.

For each parallel switching point can separately be configured:

- Voltage converter ratio (secondary)
- Synchronisations parameters
- Locking relay parameters
- Set points for isolated operation (voltage, frequency)
- Controller parameters

7.3 Operating Modes

The SYR2 features several operating modes which are described in the following.

The operating modes are provided with a rank number. If several operating modes are selected at the same time, the SYR2 operates with the operating mode of the highest rank number.

Rank	Operating mode
3	Mains parallel mode
2	Synchronisation
1	isolated operation

Synchronising Device SYR 2

Description

Corresponding parameterised limit values are only active in correspondingly assigned operating modes (see chap. 7.8.9).

The controller parameters (if configured accordingly) as well are switched depending on the operating mode (see chap. 8 and chap. 9).

7.3.1 Mains parallel Mode

The SYR2 is situated in mains parallel mode when either the SYN pulse is output as a continuous contact (see chap. 7.7) or the 'mains parallel' input function (see chap. 11.1, function number 43) is active. The SYR2 regulates voltage and frequency according to the controller parameters set for mains parallel operation or, if appropriately parameterised, with global parameters (see chap. 8 and chap. 9).

7.3.2 Synchronisation Mode

The SYR2 is situated in synchronisation mode, when the input function 'SYN clearance' (see chap. 11.1, function number 20) is active and the time of 'delay-time SYN clearance' has elapsed. The SYR2 regulates voltage and frequency according to the controller parameters set for synchronisation mode or, if appropriately parameterised, with global parameters (see chap. 8 and chap. 9).

7.3.3 Isolated operation Mode

The SYR2 is situated in isolated operation mode, when the input function 'isolated operation' (see chap. 11.1, function number 21) is active. The SYR2 regulates voltage and frequency according to the controller parameters set for isolated operation or, if appropriately parameterised, with global parameters (see chap. 8 and chap. 9).

7.4 Synchronisation

7.4.1 Synchronisation clearance

The clearance for synchronisation is performed via the input parameterised for this purpose (see chap. 11.1 function number 20).

After activating the SYN clearance input, the set time 'delay-time SYN clearance' expires. After this time has elapsed, the synchronisation clearance is active internally.

When the SYN clearance is internally active, the SYR2 starts regulating voltage and frequency accordingly to the set parameters (see chap. 8 and chap. 9).

If the delta-f clearance (see chap. 7.4.4.3) is activated, it is checked after the synchronisation clearance.

7.4.2 Syn Pulse

When the SYN clearance is active internally, all the following conditions must be fulfilled in order for the sync pulse to be output to at the correct phase position:

- SYN clearance is granted
- Switching-on clearance must be granted (see chap. 7.4.3)
- Switching-on voltage (generator) - if active and parameterised as SYN-preventing - must be reached or exceeded (see chap. 7.4.3.1)
- Switching-on frequency (generator) - if active and parameterised as SYN-preventing - must be reached or exceeded (see chap. 7.4.3.2)

Synchronising Device SYR 2

Description

- Delta-f clearance must be active (*see chap. 7.4.4.3*)
- No SYN-preventing parameterised limit value may be active (*see chap. 7.8.8*)
- Difference of voltage between grid and generator \leq Delta U max
- Difference of frequency between grid and generator \leq Delta f max
- Input function 'block switching-on' is not active (*see chap. 11.1*)

7.4.3 Switching-on clearance

The SYR2 monitors voltage and frequency of the generators for compliance with the switching-on limit values. Only when all active values are adhered, the switching-on clearance is internally enabled.

With the digital output functions under the rubric 'Switching-on' (switching-on voltage OK, switching-on frequency OK, switching-on voltage and frequency OK, switching on released), a readiness in general for switching-on can be reported to the controller.

The corresponding relay (*function 'switching-on clearance', see chap. 11.1*) is activated, when voltage and frequency of all measured phases are above of the values.

The switching-on clearance can be deactivated by means of a correspondingly parameterised (locking-) input (*function 'block switching-on', chap. 11.1*). No sync pulse will be output in this case. This does not affect the blocking relay it continues to operate.

The switching-on clearance can as well be forced via a correspondingly parameterised input ('external switching-on clearance'). The input function 'external switching-on clearance' is subordinated to the 'block switching on' input function. If both inputs are active, the switching-on is blocked.



Note: If no switching-on limit value (switching-on voltage or switching-on frequency) is active, the switching-on clearance is activated via the digital input function 'external switching-on clearance'. If this input function is also not used, the conditions are deemed fulfilled and the switching-on to the grid is enabled.

7.4.3.1 Switching-on Voltage

This setting is used to determine the SYR2 at which minimum generator voltage the synchronisation is permitted. Values from 0 up to 150 % are adjustable.

When the set limit values are undershot, the assigned relay is activated. The switching-on clearance is not granted, no SYN pulse is output.

The voltage monitoring can be deactivated (blocked) by means of a parameterisable input.

Deactivating of the limit value 'switching-on voltage' is possible.

7.4.3.2 Switching-on Frequency

This setting is used to determine the SYR2 at which minimum frequency the synchronisation is permitted. Values from 35.0 up to 65.0 Cy are adjustable.

When the set limit values are undershot, the assigned relay is activated. The switching-on clearance is not granted, no SYN pulse is output.

The frequency monitoring can be deactivated (blocked) by means of a parameterisable input.

Deactivating of the limit value 'switching-on frequency' is possible.

Synchronising Device SYR 2

Description

7.4.4 Monitoring Functions

The SYR2 features the option to activate various monitoring functions. The monitoring functions allow the downstream controller to check the compliance with the set limits, before giving the synchronisation clearance voltage and frequency. In addition to the limit values, the clearance as well as the SYN pulse can be monitored.

7.4.4.1 Clearance Monitoring

After synchronisation clearance is granted, the clearance monitoring starts. The set time of the clearance monitoring expires and generates the fault message "Clearance monitoring" after the expiry.

The time of the SYN clearance is reset as soon as the input function "SYN clearance " is inactive.

7.4.4.2 Monitoring of Synchronisation Pulse

After the SYN clearance has been carried out, the SYR2 monitors whether a synchronous pulse has been output within the set monitoring time. If no synchronisation occurs within the set time, the assigned relay as well as the collective fault relay are energised. Further subsequent SYN pulses (with the SYN clearance still active) are subject to syn-impulse-monitoring.

7.4.4.3 Delta-f Clearance

The Delta-f clearance ensures, that the generator grid is variable in frequency.

The delta-f clearance must be fulfilled before a synchronous pulse is output. The delta-f clearance can be set after the time of 'delay SYN clearance' has elapsed.

The delta-f clearance can be fulfilled in the following way:

- The generator frequency increases once by at least $\frac{\text{Target point frequency control}}{2}$ in relation to the mains frequency.

$$f_G \geq f_N + \frac{f_{\text{Target point frequency}}}{2}$$

- The input function 'clearance delta-f' is activated (see chap. 11.1 function number: 24).
- DIL switch 4 is closed (see chap. 5.1.2).

If the SYN clearance is nullified, the delta-f clearance is also reset.

7.4.5 Isolated Operation

If isolated operation is active via a digital input (factory setting: DI2), the generator voltage and the generator frequency are independently controlled to the nominal values (deviating set points are possible).

The input 'isolated operation ' is subordinated to the clearance input ('SYN clearance'), that means if both inputs are actuated at the same time, synchronising will be performed.

In isolated operation, the generator voltage and the generator frequency are controlled to the adjusted isolated operation set points. These can be set differently from the nominal values. A dead zone, in which no control takes place, can be parameterised in the controller settings.

During isolated operation, the frequency will only be controlled outside of the window 'leading frequency + dead zone'. Whilst the generator frequency moves within this window, no frequency-adjusting pulses are outputted.

Synchronising Device SYR 2

Description


7.5 Usage as Locking Relay

The SYR2 features a locking relay function (*digital outputs see chap. 12.1*). When synchronisation is enabled, this function monitors the phase angle between mains and generator and blocks the synchronisation (via relay contact) if the set deviation is exceeded. If the switch-on voltage or switch-on frequency is not reached, this contact blocks as well.

The Delta-f clearance (*see chap. 7.4.4.3*) as well as the SYN-preventing limit values (*see chap. 7.8.8*), are not relevant to the locking relay. Even the input function 'lock switching-on' has no effect on the locking relay.

7.6 Switching onto Dead Bus-Bar


The SYR2 can be parameterised in a manner, that a switching onto a so called dead bus-bar, that is a not energised bus-bar, is possible. This function has to be activated separately. Normal synchronisation will still work unchanged if the dead bus-bar is configured. If this function is activated, one of three different methods can be selected:



1. Generator to dead bus bar

The switching-on takes place to the not energised bus-bar of the leading mains (*figured left*).


The SYN pulse is output when the generator voltage lies within the set limits and the mains voltage is below the set limit value.



2. Transformer to dead bus bar

The switching-on takes place to the not energised bus-bar of the generator grid (*figured left*).

The SYN pulse is output when the values of the leading mains range within the adjusted limit values and the generator voltage (in this case transformer voltage) are below of the set limit values.



3. Bus rare to dead bus bar

The switching-on can be done as well to the not energised bus-bar of the leading mains, as to the not energised bus-bar of the generator grid, or if both bus bars are de-energized or voltage-carrying (then with synchronisation).

The function 'dead bus-bar active' can be assigned to an output (*see chap. 12.1 - Digital Outputs – function No. 43*).

Three parameters are configurable for the dead bus-bar functionality:

- Maximum bus-bar voltage (in % of the nominal voltage)
- Minimum generator - / transformer - / bus-bar voltage (in % of U_G)
- Switching-on delay (in seconds)

Synchronising Device SYR 2


Description

After the clearance of the synchronisation (see chap. 11.1 – function No. 20), first the delay time for synchronisation (ex works setting: 2,0 s) elapses. After this time is elapsed, the switching on delay (ex works setting: 2,0 s) goes on. During this time lapse the SYR2 checks, whether the mains voltage (all phases of the grid) is continuously below the adjusted limit value maximum bus-bar voltage (ex works setting: 10 %) and the generator voltage is continuously above the adjusted limit value for the minimum generator voltage (ex works setting: 80 %).

After the switch on delay time is elapsed, a sync pulse with the adjusted pulse length is emitted. When the sync pulse is ended, a new monitoring of 5 seconds starts and a once more sync pulse will be emitted. This process will be repeated until either the synchronisation clearance is removed, or the limit value conditions for the activation of the 'dead bus-bar' are no longer met.

Furthermore, the output function 'bus-bar voltage-free' (No. 44) is available. An output relay parameterised with this function is activated when the set dead bus-bar specifications are met and the synchronisation is released via a digital input.

7.7 Synchronisation Pulse as permanent Contact



The synchronisation pulse also may be output by the SYR2 as permanent contact.

The permanent contact setting is made by entry of the time '0,0 s' as duration for the synchronisation impulse (*setting via device management – see figure on the left*). With this setting, the relay picks up at the first synchronisation time point and remains tightened, until the synchronisation clearance is revoked.

7.8 Limit Values

7.8.1 Behaviour of the Limit Values

All limit values can be adjusted and assigned to a relay separately. A set and active limit value is displayed as a triggering message in the display, regardless of whether the limit value has been laid to a relay or to one of the fault messages. Each limit value message leads to the activation of the internal collective fault message and can optionally be linked to the freely configurable collective messages.

7.8.2 Triggering of Limit Values

The triggering is basically carried out when the respective measured value exceeds or falls short of the set limit value and the set delay time has elapsed. Each trigger value has its own delay time. The delay times are individually adjustable for each limit value in the range from 0.05 s to 999.9 s.

Switching back after a limit value triggering occurs when the respective measured value has again fallen below or exceeded the set limit value plus hysteresis.

The message duration can be set between 0.1 s and 6000.0 s for each relay in the configuration of the outputs. The set value causes the corresponding relay contact to remain accessed at least for the set time, even if the exceeding or shortfall of the limit value is of shorter duration.


Synchronising Device SYR 2

Description

7.8.3 Manually / Automatically Reset

Factory-default all limit values are set to automatical reset. This automatical reset can be disabled for each individual limit value. If the auto-reset is activated, correspondingly configured fault messages and limit value messages are automatically reset as soon as the triggering condition no longer exists.

Limits for which the automatic reset is deactivated, can only be reset by means of a correspondingly configured digital input (see *chap. 11.1* - Digital Inputs) or by long actuating of the reset-key (enter Button) while main screen is displayed. The manual reset works edge-controlled and resets all limit messages for 1 s. If limit value messages are still pending, they are again indicated with the end of the reset time.




Note: The automatic reset is basically deactivated for all parameterised limit value messages by closing the DIL switch S1 (ON).




Note: Resetting the fault messages by means of the Enter key (hold pressed for 2 s) is only possible while the main screen is displayed.

7.8.4 Disable limit values

Individual or all limit value messages can be deactivated by means of the parameterisable digital inputs (see *chap. 11.1*). Up to 3 blocking functions can be assigned to each limit value. The global lock function 'disable all' always deactivates all active limit messages. If the input is set, the corresponding limit value messages are suppressed. The following lock functions are available:

- disable all limit values (default E1)
- disable 1
- disable 2
- disable 3




7.8.5 Central Fault

All limit value messages are entered into the central collective fault signal if the limit value message is activated, the limit value is exceeded respective fallen short of and the delay time has elapsed.

Synchronising Device SYR 2

Description

7.8.6 Central Fault 1+2



The device offers the possibility to form two independent collective fault signals. These are composed of the individual limit values. The operator thus can configure a specific event himself.

By activating the corresponding assignment, each adjustable limit value can be added to the 'collective fault 1' and/or 'collective fault 2'.

Example:

Limit value setting: at Undervoltage 1,
Underfrequency 2 and Vector shift 1

☒ Central fault 1

Setting digital outputs: function relay 5

22 = Central fault 1


This combination of the settings causes the relay 5 to be energised when at least one of the 3 limit value events occurs.

7.8.7 Display First Error

By means of parameterisation, the device can be specified to as whether there should only be a first value triggering (first error), or also the triggering of subsequent faults. 'Display first error only' means, that in the case of a triggering of e.g. the limit value Underfrequency 1 at a loss of one phase, an a triggering of e.g. Undervoltage 1, which is inevitably occurring as a result, no longer is evaluated. If 'display first error only' is deactivated, all the triggerings are displayed and stored in the internal error memory in the order of occurrence.

7.8.8 SYN-preventing Limit Value

Each limit value (with the exception of the switching-on and monitoring limit values) can be parameterised so that it is sync preventing. Such a limit value prevents synchronisation as long as it is triggered.




7.8.9 Operating Mode depended Release (only generator Limit Values)

The generator limit values can be activated or deactivated individually for each operating mode. Triggerings of the limit values then occur only within the operating modes activated therefor. If none of the four operating modes is activated, the generator limit values are triggered in all operating modes.

The following options are available for the generator-specific triggering of the generator limit values:

- Release at readiness for switching-on
- Release at isolated operation
- Release at SYN operation
- Release at mains parallel operation




Note: mains limit values are in all operating modes activated.

Synchronising Device SYR 2

Description

7.9 Limit Value Settings

Each limit value can be set individually and is shown below.

Percentage-wise adjustable limit values always refer to the respective configured nominal value.

7.9.1 Rotary Field Monitoring (Mains and/or Generator)

Function	Range	Hysteresis	Delay time	Permissible deviation
Monitoring of rotary field mains / generator	left / right	10°	0.5 s	+/-1.0° -0.01 / +0.02 s

The respective smallest or largest of the three phase angles is used as the trigger criterion for the rotary field monitoring. If it exceeds- or falls below 180°, the signal 'rotary field error' is generated and output. Thereby the SYR2 differentiates according to the internal and external rotary field, in order to detect any faults in the wiring. The rotary field error has no effect on the other error signals. The monitoring can be adjusted on left or right rotary field by the parameterisation software. Ex works, the rotary field monitoring of the SYR2 is not activated. Even if the rotary field monitoring is deactivated, the SYN pulse and the locking relay will not switch on when the rotating fields are in the opposite direction. An opposing rotating field is shown in the display during synchronization. If the rotating fields are in opposite directions and the limit value "rotary field monitoring" is inactive, the clockwise rotation is assumed to be the right one. The anti-clockwise system is displayed as an error.



Note: For the monitoring of the rotation field, hysteresis and delay time are fixed preset and can not be adjusted.

7.9.2 Monitoring of Angle Error (Mains and/or Generator)

Function	Range	Hysteresis	Delay time	Permissible deviation
Angle min. mains	-5.0 ... -60.0°	1° ... 20°	0.05 s ... 999.99 s	+/-0.5° -0.01 / +0.02 s
Angle max. mains	5.0 ... 60.0°	1° ... 20°	0.05 s ... 999.99 s	+/-0.5° -0.01 / +0.02 s
Angle min. generator	-5.0 ... -60.0°	1° ... 20°	0.05 s ... 999.99 s	+/-0.5° -0.01 / +0.02 s
Angle max. generator	5,0 ... 60,0°	1° ... 20°	0,05 s ... 999,99 s	+/-0,5° -0,01 / +0,02 s

The angle error monitoring is in two stages executed and checks the deviation of the phase angle of two successive phases L1-L2, L2-L3, L3-L1 from the normal case (120°). The amount of the deviation of 120° is used as limit value specification.

Example:

Angle error		
Angle 1	15°	If the phase angle L1-2 falls short of the value of 105° (120°-15°) or if it exceeds the value of 135° (120° + 15°) for the duration of 0.08 s, the signal 'Angle error 1' is set.
Delay time	0.08 s	Switching back occurs as soon, as the angle than again exceeds the value of 106° (120° - 15° + 1°), falls below of the value of 134°.
Hysteresis	1°	

Synchronising Device SYR 2

Description

7.9.3 Voltage Triggering – Under-/Overvoltage (Mains and/or Generator)

Function	Range	Hysteresis	Delay time	Permissible deviation	
Undervoltage mains	10,0 ... 199,9 %	0,5 ... 50,0 %	0,05 s ... 999,99 s	+/-0,1 %	-0,01 / +0,02 s
Overvoltage mains	10,0 ... 199,9 %	0,5 ... 50,0 %	0,05 s ... 999,99 s	+/-0,1 %	-0,01 / +0,02 s
Undervoltage generator	10,0 ... 199,9 %	0,5 ... 50,0 %	0,05 s ... 999,99 s	+/-0,1 %	-0,01 / +0,02 s
Overvoltage generator	10,0 ... 199,9 %	0,5 ... 50,0 %	0,05 s ... 999,99 s	+/-0,1 %	-0,01 / +0,02 s

Each limit value has its own triggering delay.

Example:

Undervoltage

Limit value	90 %
Delay time	0,08 s
Hysteresis	0,5 %

If the voltage of one phase falls short of 90,0 % (207 V at 230 V nominal voltage), the signal 'Undervoltage 1' is set after 0.08 s.

The switching back occurs as soon as all phases have again exceeded the value of 90,5 % (208,2 V).

7.9.4 Voltage Asymmetry Triggering (Mains and/or Generator)

Function	Range	Hysteresis	Delay time	Permissible deviation	
Asymmetry mains	1,0 ... 100,0 %	0,5 ... 50,0 %	0,05 s ... 999,99 s	+/-0,1 %	-0,01 / +0,02 s
Asymmetry generator	1,0 ... 100,0 %	0,5 ... 50,0 %	0,05 s ... 999,99 s	+/-0,1 %	-0,01 / +0,02 s

For the asymmetry monitoring, a limit value for the maximum permissible deviation of the voltage between two phases has to be entered in % of the nominal voltage. The voltage asymmetry limit is triggered as well on loss of a phase voltage.

Example:

Asymmetry

Limit value	10 %
Delay time	0,05 s
Hysteresis	1,0 %

If the voltage difference between two phases exceeds 10.0 % (L1 = 235 V, L2 = 211 V, L3 = 230 V at 230 V nominal voltage), the signal 'Voltage asymmetry' is set after 0.05 s. The switching back occurs as soon as the difference becomes less than 9 % (10.0 % - 1.0 %).

Synchronising Device SYR 2

Description

7.9.5 Deviation of Voltage Mean Value (Mains and/or Generator)

Function	Range	Hysteresis	Delay time	Permissible deviation
Mean value dev. mains	1,0 ... 100,0 %	0,5 ... 50,0 %	0,05 s ... 999,99 s	+/-0,1 % -0,01 / +0,02 s
Mean value dev. generator	1,0 ... 100,0 %	0,5 ... 50,0 %	0,05 s ... 999,99 s	+/-0,1 % -0,01 / +0,02 s

If deviation of mean value is enabled, the SYR2 monitors the average of the 3 external conductor voltages on fall short of the set limit value according to the following formula:

$$X \% < ((U12 \% + U23 \% + U31 \%) / 3)$$

Example:

Mean value

Limit value	90 %
Delay time	1,00 s
Hysteresis	1,0 %

If, at U12 = 91,0 %, U23 = 90,3 %, U31 = 78,7 %, the mean value is 86,6 %, triggering is executed after 1.0 s. Die Switching back occurs as soon as the mean value than again exceeds 91.0 %.

7.9.6 Frequency Triggering Under-/Overfrequency (Mains and/or Generator)

Function	Range	Hysteresis	Delay time	Permissible deviation
Underfrequency mains	35,00 ... 65,00 cy	0,05 ... 2,00 cy	0,05 s ... 999,99 s	+/-0,01 cy -0,01 / +0,02 s
Overfrequency generator	35,00 ... 65,00 cy	0,05 ... 2,00 cy	0,05 s ... 999,99 s	+/-0,01 cy -0,01 / +0,02 s
Underfrequency mains	35,00 ... 65,00 cy	0,05 ... 2,00 cy	0,05 s ... 999,99 s	+/-0,01 cy -0,01 / +0,02 s
Overfrequency generator	35,00 ... 65,00 cy	0,05 ... 2,00 cy	0,05 s ... 999,99 s	+/-0,01 cy -0,01 / +0,02 s

For the under- / overfrequency detection, two different limit values are adjustable. Each limit value has its own triggering delay time.

Example:

Overfrequency Mains

Limit value	51,20 cy
Delay time	0,08 s
Limit value	0,10 cy

If the frequency of one phase exceeds 51.20 cy, the signal 'Overfrequency 1' is set after 0,08 s. The switching back occurs as soon as the frequency falls below 51.10 cy again.

Synchronising Device SYR 2

Description

7.9.7 Vector Shift Triggering (Mains)

Function	Range	Hysteresis	Delay time	Permissible deviation	
Vector shift mains	5,0 ... 45,0°	-	0,03 s	+/-0,1°	-0,01 / +0,02 s

The vector shift detection takes place two staged and can be adjusted in various combinations. The input is done in angular degrees relative to a full-wave (period) with 360°. The signal 'Vector shift' features a systematic delay of approximately 0,03 s.

Possible combinations are:

Example:

Vector shift mains		No.	Function
Limit value	8.0 °	0	L1 or L2 or L3
Combination	L1 and L2 and L3	1	only L1
		2	only L2
		3	only L3
		4	L1 and L2 and L3
		5	L1 and L2 and L3 (differenced vector shift)

If a vector shift of at least 8.1° occurs at all 3 phases, the signal 'Vector shift mains' will be generated and output.

7.9.8 Delta f to Delta t (ROCOF) (Mains)

Function	Range	Hysteresis	Delay time	Permissible deviation	
ROCOF Mains	0,01 ... 10,00 cy/s	-	0,05 ... 999,99 s	+/-0,01 cy	-0,01 / +0,02 s

The as well two stage executed limit value function $\Delta f/\Delta t$ (ROCOF - rate of change of frequency) offers the possibility to detect frequency changes alternatively or parallel to the vector shift detection.

Example:

ROCOF Mains		The triggering occurs, when the frequency alters with a speed of 0,5 Cy/s for a minimum period of 0,1 s. In this example at an alteration of >0,05 cy in 0,1 s.
Limit value	0,50 cy/s	
Delay time	0,10 s	

7.9.9 Slip

Function	Range	Hysteresis	Delay time	Permissible deviation	
Slip	-0,01 ... -50,00 cy	-	0,2 ... 999,99 s	+/-0,01 cy	-0,01 / +0,02 s

The Slip is calculated as follows:

$$s = |f_s - f_g|$$

Example:

Slip		The triggering occurs when the slip is greater than 0.5 cy for the duration of at least 0.1 s.
Limit value	0,50 cy	Switching back occurs as soon, as the slip is smaller than 0.3 cy.
Delay time	0,10 s	
Hysteresis	0,2 cy	


Synchronising Device SYR 2

Description

7.10 Trigger Memory

The SYR2 stores the measured values for the respective limit value triggerings. The error memory can store the values of up to 58 trigger events. The trigger values are permanently stored in the flash memory of the device with the date and time and are retained even in case of loss of the auxiliary voltage. The number of detected triggerings is stored in a counter (maximum 65,000; can not be erased; reset to 0 if exceeded). The trigger values can be read on the device. The trigger memory can be read out as well via GV-2 (see chap. 7.10.1).

The output of the triggerings on the device's graphic display is called up by closing the DIL switch S4 (see chap. 5.1.2 – DIL switches) while in the operation mode the main screen is displayed. First, the last triggering is shown. Actuating the UP button (for the function of the buttons see chap. 5.1.1 - Buttons), the different values of the triggering can be viewed. Using the Enter button, one can scroll backwards through the stored triggerings. When the oldest stored triggering is reached, the display returns back to the most recently stored triggering.




The stored triggering values are cleared by holding pressed down the UP button for approx. 10 seconds while the DIL switch S4 is closed (display output figured right). Then all previously stored triggering values, but not the counter reading for all triggerings (refer above), are erased.


```

** ACHTUNG **
löschen      /   delete
Speicher     /   memory
              in   3.7 s
  
```

7.10.1 Reading out the Trigger Memory



The trigger memory of the SYR2 can be read out with the parameterisation software GV-2 by clicking the corresponding button (figured left). In the window that appears thereupon, all stored fault messages are listed chronologically. The fault messages can be stored as plain text file (*.txt) on the PC system.





Synchronising Device SYR 2

Description

7.11 Programmable Switching Points

In addition to the adjustable limit values, the SYR2 has 3 programmable switching points. Each switching point can be assigned to a selection of functions. Hereby switching behaviour, hysteresis and a deceleration time can be set. The following values are available:

No.	Function	Description
0	without function	Output is inactive
1	Voltage mains L1-N	Mains voltage L1 scaled in xx.x % of the nominal voltage
2	Voltage mains L2-N	Mains voltage L2 scaled in xx.x % of the nominal voltage
3	Voltage mains L3-N	Mains voltage L3 scaled in xx.x % of the nominal voltage
4	Voltage mains average L1-N / L2-N / L3-N	Mean value of the mains neutral point voltages in xx.x % of the nominal voltage
5	Voltage mains L1-L2	Mains voltage L12 scaled in xx.x % of the nominal voltage
6	Voltage mains L2-L3	Mains voltage L23 scaled in xx.x % of the nominal voltage
7	Voltage mains L3-L1	Mains voltage L31 scaled in xx.x % of the nominal voltage
8	Voltage mains average L12 / L23 / L31	Mean value of the mains external conductor voltages in xx.x % of the nominal voltage
9	Voltage generator L1-N	Generator voltage L1 scaled in xx.x % of the nominal voltage
10	Voltage generator L2-N	Generator voltage L2 scaled in xx.x % of the nominal voltage
11	Voltage generator L3-N	Generator voltage L3 scaled in xx.x % of the nominal voltage
12	Voltage generator average L1-N / L2-N / L3-N	Mean value of the generator neutral point voltages in xx.x % of the nominal voltage
13	Voltage generator L1-L2	Generator voltage L12 scaled in xx.x % of the nominal voltage
14	Voltage generator L2-L3	Generator voltage L23 scaled in xx.x % of the nominal voltage
15	Voltage generator L3-L1	Generator voltage L31 scaled in xx.x % of the nominal voltage
16	Voltage generator average L12 / L23 / L31	Mean value of the generator external conductor voltages in xx.x % of the nominal voltage
17	Mains L1	Mains frequency L1 scaled in xx.xx Cy
18	Generator L1	Generator frequency L1 scaled in xx.xx Cy



Each switching point can be assigned to a relay output (see *chap. 12.1 - Digital Outputs*).

The output relay then switches according to the parameterisation when the respective measured value is exceeded or undershot. No messages are displayed.



Note: Switching points are NOT considered in the fault message processing!

Synchronising Device SYR 2

Description

8 PID-T1 Controller

For controlling of the voltage and the frequency, the SYR2 features two independent, integrated PID-T1 controllers, which can be assigned to the two available analogue outputs.

'PID-T1 1' regulates the voltage, 'PID-T1 2' the frequency.

To activate the PID-T1 controllers, the analogue outputs on the device must be activated and the PID-T1 controllers must be assigned to the respectively provided analogue output.

If a PID controller is assigned to an analogue output, the analogue output can be applied with an offset. This causes an raising in the analogue output quantity by the set amount; thus, for example, a control difference of '0' at an analogue output offset of 5 V, can cause an output voltage of 5 V.

In the operating modes, the following controller set points are underlying:

Operating mode	Voltage controller	Frequency controller
isolated operation	<i>nominal voltage island operation</i>	<i>nominal frequency island mode</i>
Sync operation	<i>mains voltage</i>	<i>mains frequency + x</i> (x: adjustable)
Mains parallel	<i>mains voltage</i>	<i>mains frequency</i>

Each parallel switching point can be configured with its own controller parameter set. It is also possible to specify independent controller parameters for the individual operating states.

8.1 Controller Ramps

On clearance respectively blocking, a ramp time can be set in each case in order to reach the set point value within the set time, thus avoiding jumps. The ramp time is adjustable in the range from 0.0 s to 600.0 s.

8.2 Dead Zone

For the target point, a dead zone in x.x% of the set point can be set. If the actual value reaches this range, the control is stopped and continues only after leaving the set range. The dead zone can be adjusted in the range from 0 to 50.0%.

8.3 Clearance Delay

A clearance delay can be set for activating the controllers. This time causes the respective controller to become active only after this time has expired. The clearance delay is adjustable in the range from 0.0 s to 600.0 s.


Synchronising Device SYR 2

Description

8.4 Controller Parameters

The seven following values are adjustable for the PID-T1 controllers:

	Function	Range	Permissible deviation
1.	Amplification K_p	0.01 ... 10.00	-
2.	Integration time T_n	0.0 ... 999.9 s	+/- 0.1 s
3.	Derivative time T_v	0.0 ... 99.9 s	+/- 0.1 s
4.	Readjust time T_1	0.0 ... 99.9 s	+/- 0.1 s
5.	Release delay	0.0 ... 600.0 s	+/- 0.5 s
6.	Ramp time	0.0 ... 600.0 s	+/- 0.5 s
7.	Dead zone	0.0 ... 50.0 %	0.02 %



Synchronising Device SYR 2

Description

9 Pulse Controller

For controlling of the voltage and the frequency, the SYR2 features two independent, integrated pulse controllers, whose pulses can be assigned to the digital outputs (relays) (see *chap. 12.1 - Digital Outputs*).

'Pulse controller 1' regulates the voltages, 'Pulse controller 2' the frequency.

To activate the corresponding pulse controller, at least one of its control pulses must be assigned to a digital output.

The control impulses (+/-) output by the pulse controllers can also be set via appropriately parameterised digital inputs.

In the operating modes, the following controller set points are underlying:

Operating mode	Voltage controller	Frequency controller
Isolated operation	<i>nominal voltage island operation</i>	<i>nominal frequency island mode</i>
Sync operation	<i>mains voltage</i>	<i>mains frequency + x</i> (x: adjustable)
Mains parallel	<i>mains voltage</i>	<i>mains frequency</i>


Each parallel switching point can be configured with its own controller parameter set. It is also possible to specify independent controller parameters for the individual operating states.

Both pulse controllers can be configured as pulse frequency controllers or as pulse width controllers (this setting applies to each operating mode of a parallel switching point).

The controllers can be released respectively blocked via parameterisable input functions.

The set point usually is set internally. With the Miniature PC option, the set point specification from the external source is possible.

9.1 PFM (Pulse Frequency Modulation)



In the case of modulation type PFM, the control pulse has a fixed pulse length respectively pulse duration. The pulse pause or the frequency varies depending on the control difference (and the set amplification). The larger the deviation, the more (equal-length) pulses per minute.

Synchronising Device SYR 2

Description


9.1.1 Controller Parameters

For the PFM pulse controller, four values (different for each PSP, different for each operating mode) are adjustable.

Parameter	Range	Tolerance
Amplification Imp/%	0,01 ... 99,99	-
Pulse duration	0,1 ... 999,9 s	+/- 0,05 s
Release delay	0,0 ... 600,0 s	+/- 0,5 s
Dead zone	0,0 ... 50 %	0,02 %

- Amplification Kp in impulses/% per minute:
The value set here corresponds to a pulse count of Kp pulses per minute with a % control deviation.
Example 1: Kp = 1.00, control deviation = 2 % -> 2 pulses per minute
Example 2: Kp = 5.00, control deviation = 2 % -> 10 pulses per minute
Example 3: Kp = 0.10, control deviation = 12 % -> 1.2 pulses per minute
- Pulse duration T adjustable in 0.1 sec steps:
The value set here determines the switch on duration of the associated output relay. If the interval between 2 control pulses is less than the switch on duration, the output relay will change over to the permanent contact.
- Release delay in 0.1 sec steps:
The controller is blocked after activation for the duration of the enable delay.
- Dead zone in 0.1 % steps:
If the control deviation is less equal the set dead zone, the controller does not output any control pulses.

9.2 PWM (Pulse Width Modulation)



At the modulation type PWM, the frequency is fixed. The pulse length or pulse duration changes depending on the control deviation (and the adjusted amplification).

If no control deviation occurs, no pulse is output. At a 100 % control deviation (and an amplification of 1) a permanent pulse is output.

Synchronising Device SYR 2

Description

9.2.1 Controller Parameters

For the PWM pulse controller, four values (different for each PSP, different for each operating mode) are adjustable.

Parameter	Range	Tolerance
Amplification Imp/%	0,01 ... 99,99	-
Period duration	0,1 ... 999,9 s	+/- 0,05 s
Release delay	0,0 ... 600,0 s	+/- 0,5 s
Dead zone	0,0 ... 50 %	0,02 %

- **Amplification Kp**
The value set here corresponds to the ratio between pulse and pause at one per cent of the control difference.
Example 1: Kp = 1.00 control difference = 2 % → 2 % of the period duration, the output is accessed
Example 2: Kp = 5.00 control difference = 2 % → 10 % of the period duration, the output is accessed
Example 3: Kp = 20.00 control difference = 5 % → 100 % of the period duration, the output is accessed.
- **Period duration T adjustable in 0.1 sec steps**
The value set here determines the period duration of the output relay. If the pause time between 2 control pulses gets less than the switch-on duration, the output relay switches to permanent contact.
- **Release delay in 0.1 sec steps:**
The controller is blocked after activation for the duration of the enable delay.
- **Dead zone in 0.1 % steps:**
If the control deviation is less equal the set dead zone, the controller does not output any control pulse.

9.3 Dead Zone

For the target point, a dead zone in x.x % of the set point can be adjusted. If the actual value reaches this range, the control is stopped and continues only after leaving the set range. The dead zone can be adjusted in the range from 0 to 50.0 %.

9.4 Release Delay

For the activating the controllers, a clearance delay time can be set. This setting causes the respective controller only becomes active when, after the input function is set, this time has expired. The clearance delay is adjustable in the range from 0.0 s to 600.0 s.

Synchronising Device SYR 2

Description

10 Electronic Potentiometer

The SYR2 features two internal electronic potentiometers whose 'outputs' can be laid on the existing analogue outputs.

The 'Electronic Poti 1' reacts on voltage control pulses, the 'Electronic Poti 2' reacts on frequency control pulses.

The control pulses of the pulse controllers are internally linked as actuating variables for the electronic potentiometers. In addition, digital input functions (see *chap. 11.1 - Digital Inputs*) can be used for adjusting and resetting the potentiometers (control pulse higher, control pulse lower, reset).


If the potentiometer is reset (see *chap. 11.1 function number: 35, 36*), its output jumps to the set offset.

10.1 Parameters

The following parameter are adjustable:

Parameter	Range	Tolerance
Swing	0,01 ... 10,00 V	
Offset	0,00 ... 10,00 V	+/- 0,05 s
Ramp	0,1 ... 250,0 s	+/- 0,5 s

- **Swing:** This parameter determines the maximum alteration from the offset, in the plus and minus direction.
- **Offset:** This parameter determines the 'zero point' of the electronic potentiometer. The output jumps to this value, when the potentiometer is reset.
- **Ramp:** This parameter determines the speed of change of the output. The potentiometer requires the set ramp time from the lowest to the highest parameterised value: $2 \times \text{swing}$.



Synchronising Device SYR 2

Description

11 Inputs

11.1 Digital Inputs

The SYR2 features 3 digital inputs, which can be assigned to one of the following functions:

No.	Function	Description
0	deactivated	Input is not active. Allocation of an output with the terminal of this input is however possible.
1	Global disable	All limit value messages are suppressed as long as the input is active.
2	Disable 1	All limit value messages, which are parameterised with lock 1 are suppressed as long as the input is active.
3	Disable 2	All limit value messages, which are parameterised with lock 2 are suppressed as long as the input is active.
4	Disable 3	All limit value messages, which are parameterised with lock 3 are suppressed as long as the input is active.
5	Fault reset	Reset of limit value messages, which are not set to 'Auto reset'.
6	Change language	Changing of the display language depending on the parameter setting. The language switching can be deactivated.
10	Feedback DO1 REL1 – KL9	Monitoring of the feedback of the contactor connected to DO1. In the event of a fault, the 'collective fault' signal is set after 0.5 s (see chap. 11.1.1 – <i>Monitoring of the Relay- (Contactor-) Acknowledgement</i>).
11	Feedback DO2 REL2 – KL10	Monitoring of the feedback of the contactor connected to DO2. In the event of a fault, the 'collective fault' signal is set after 0.5 s (see chap. 11.1.1 – <i>Monitoring of the Relay- (Contactor-) Acknowledgement</i>).
12	Feedback DO3 REL3 – KL11	Monitoring of the feedback of the contactor connected to DO3. In the event of a fault, the 'collective fault' signal is set after 0.5 s (see chap. 11.1.1 – <i>Monitoring of the Relay- (Contactor-) Acknowledgement</i>).
13	Feedback DO4 REL4 – KL12	Monitoring of the feedback of the contactor connected to DO4. In the event of a fault, the 'collective fault' signal is set after 0.5 s (see chap. 11.1.1 – <i>Monitoring of the Relay- (Contactor-) Acknowledgement</i>).
14	Feedback DO5 REL5 – KL13/14/15	Monitoring of the feedback of the contactor connected to DO5. In the event of a fault, the 'collective fault' signal is set after 0.5 s (see chap. 11.1.1 – <i>Monitoring of the Relay- (Contactor-) Acknowledgement</i>).
15	Feedback DO6 REL6 – KL26/27	Monitoring of the feedback of the contactor connected to DO6. In the event of a fault, the 'collective fault' signal is set after 0.5 s (see chap. 11.1.1 – <i>Monitoring of the Relay- (Contactor-) Acknowledgement</i>).
20	SYN clearance	Release of the synchronisation.
21	Isolated operation	Isolated operation is activated (Input is subordinated to SYN clearance. If both inputs are set, SYN clearance is selected).
22	External switch-on clearance	The switching-on clearance can be set external.

Synchronising Device SYR 2

Description

No.	Function	Description
23	disable switch-on	Locks the switching-on. This input is superordinated to the external switching-on clearance. If both inputs are active, the switching-on is blocked.
24	delta-f clearance	The internal delta-f monitoring can be 'levered out' by this input function, so that the result of the monitoring is positive.
25	Show synchronoscope	The synchronoscope is displayed, when the input is set.
26	PSP choice 2	Parallel switching point 2 is selected.
27	PSP choice 3	Parallel switching point 3 is selected.
32	PSP choice bit 1	Binary input 1 for the PSP selection
33	PSP choice bit 2	Binary input 2 for the PSP selection
34	PSP choice bit 3	Binary input 3 for the PSP selection
35	Electronic potentiometer voltage reset	The voltage output of the electronic potentiometer is reset (jumps to the set offset).
36	Electronic potentiometer frequency reset	The frequency output of the electronic potentiometer is reset (jumps to the set offset).
37	Control pulse voltage +	The selected regulation increases the voltage of the generator.
38	Control pulse voltage -	The selected regulation decreases the voltage of the generator.
39	Control pulse frequency +	The selected regulation increases the frequency of the generator.
40	Control pulse frequency -	The selected regulation decreases the frequency of the generator.
41	PID controller voltage reset	The PID-T1 controller 1 (voltage) is reset (switches onto the adjusted offset).
42	PID controller frequency reset	The PID-T1 controller 2 (frequency) is reset (switches onto the adjusted offset).
43	Mains parallel operation	Mains parallel operation is activated.

11.1.1 Monitoring of the Relay- (Contactor-) Acknowledgement

If a digital input is assigned with the feedback function, the corresponding message and the collective message are set after 0.5 s, if the acknowledgement contact of the corresponding relay does not correspond to the state of the relay.

Synchronising Device SYR 2

Description

12 Outputs

12.1 Digital Outputs

The SYR2 features 3 groups of digital outputs (DO1 - DO4, DO5 and DO6) with in total 6 relays. One of the following functions can be assigned to each of these:

No.	Function	Description
0	Without function	The output is deactivated. If the output is parameterised as per closed circuit principle, the relay is permanently energised.
1	Ready for use	The corresponding relay is energised, when the SYR2 is ready for operation.
2	Central fault	The corresponding relay is energised, when the 'collective fault' is set.
3	Central fault 1	The corresponding relay is energised, when the 'collective fault 1' is set.
4	Central fault 2	The corresponding relay is energised, when the 'collective fault 2' is set.
5	Rotary field error mains	The corresponding output relay is activated if the applied rotary field of the mains does not match the parameterised rotary field (right or left).
6	Rotary field error generator	The corresponding output relay is activated if the applied rotary field of the generator does not match the parameterised rotary field (right or left).
7	Rotary field mains & generator OK	The associated output relay is activated when the applied rotary fields of the mains as well as of the generator coincide with the parameterised rotary field (right or left).
8	Angle mains	The associated output relay is activated when the limit value 'angle mains' is exceeded and the delay time has elapsed.
9	Angle generator	The associated output relay is activated when the limit value 'angle generator' is exceeded and the delay time has elapsed.
10	Angle OK	The associated output relay is activated if neither the limit value 'angle mains' nor the limit value 'angle generator' has been exceeded.
11	Undervoltage mains	The corresponding output relay is activated when the limit value 'Undervoltage Mains' is undershot and the delay time has elapsed.
12	Undervoltage generator	The corresponding output relay is activated when the limit value 'Undervoltage Generator' is undershot and the delay time has elapsed.
13	Undervoltage mains or generator	The associated output relay is activated when either the limit value 'Undervoltage Mains' or the limit value 'Undervoltage Generator' is undershot and the delay time has elapsed.
14	Overvoltage mains	The corresponding output relay is activated when the limit value 'Overvoltage Mains' is exceeded and the delay time has elapsed.
15	Overvoltage generator	The corresponding output relay is activated when the limit value 'Overvoltage Generator' is exceeded and the delay time has elapsed.
16	Overvoltage mains or generator	The associated output relay is activated when either the limit value 'Overvoltage Mains' or the limit value 'Overvoltage Generator' is exceeded and the delay time has elapsed.

Synchronising Device SYR 2

Description

No.	Function	Description
17	Asymmetry mains	The corresponding output relay is activated, when the limit value 'Asymmetry Mains' is exceeded and the delay time has elapsed.
18	Asymmetry generator	The corresponding output relay is activated, when the limit value 'Asymmetry Generator' is exceeded and the delay time has elapsed.
19	Mean value mains	The corresponding output relay is activated, when the limit value 'Mean Value Mains' is exceeded and the delay time has elapsed.
20	Mean value generator	The corresponding output relay is activated, when the limit value 'Mean Value Generator' is exceeded and the delay time has elapsed.
21	Voltage quality mains	The corresponding output relay is activated, when the limit value 'Voltage Quality Mains' is exceeded and the delay time has elapsed.
22	Voltage mains OK	The corresponding output relay is activated, when the limit values 'Undervoltage Mains' and 'Overvoltage Mains' are not active.
23	Voltage generator OK	The corresponding output relay is activated, when the limit values 'Undervoltage Generator' and 'Overvoltage Generator' are not active.
24	Underfrequency mains	The corresponding output relay is activated when the limit value 'Underfrequency Mains' is undershot and the delay time has elapsed.
25	Underfrequency generator	The corresponding output relay is activated when the limit value 'Underfrequency Generator' is undershot and the delay time has elapsed.
26	Underfrequency mains or generator	The associated output relay is activated when either the limit value 'Underfrequency Mains' or the limit value 'Underfrequency Generator' is undershot and the delay time has elapsed.
27	Overfrequency mains	The corresponding output relay is activated when the limit value 'Overfrequency Mains' is exceeded and the delay time has elapsed.
28	Overfrequency generator	The corresponding output relay is activated when the limit value 'Overfrequency Generator' is exceeded and the delay time has elapsed.
29	Overfrequency mains or generator	The associated output relay is activated when either the limit value 'Overfrequency Mains' or the limit value 'Overfrequency Generator' is exceeded and the delay time has elapsed.
30	Vector shift mains	The corresponding output relay is activated when the limit value 'Vector Shift Mains' is exceeded and the delay time has elapsed.
31	ROCOF mains	The corresponding output relay is activated when the limit value 'ROCOF Mains' is exceeded and the delay time has elapsed.
32	Slip	The corresponding output relay is activated when the limit value 'Slip' is exceeded and the delay time has elapsed.
33	Frequency mains OK	The corresponding output relay is activated when the limit values 'Underfrequency Mains' and 'Overfrequency Mains' are not active.
34	Frequency generator OK	The corresponding output relay is activated when the limit values 'Underfrequency Generator' and 'Overfrequency Generator' are not active.
35	Switch-on voltage OK	The associated output relay is activated when the switching-on voltage is reached.

Synchronising Device SYR 2

Description

No.	Function	Description
36	Switch-on voltage not OK	The associated output relay is activated when the switching-on voltage not is reached.
37	Switch-on frequency OK	The associated output relay is activated when the switching-on frequency is reached.
38	Switch-on frequency not OK	The associated output relay is activated when the switching-on frequency not is reached.
39	Switch-on voltage AND Switch-on frequency OK	The corresponding output relay is activated when the Switching-on voltage and the Switching-on frequency are reached.
40	Switching-on released	The corresponding output relay is activated when the Switching-on is released (<i>see chap. 7.4.3</i>).
41	Release error	The corresponding output relay is activated when the limit value 'Release Monitoring' is triggered.
42	Sync pulse error	The corresponding output relay is activated when the limit value 'Sync Pulse Monitoring' is triggered.
43	Dead bus bar active	The associated output relay is activated when the SYN clearance is granted and the voltage of the corresponding dead bus-bar ranges below of the adjusted voltage and the voltage of the energised ranges above of the adjusted voltage.
44	Bus-bar not energised	The associated output relay is activated when the SYN clearance is granted and the voltage of the corresponding dead bus-bar ranges below of the adjusted voltage.
45	Impulse controller voltage +	The corresponding output relay is accessed when the voltage impulse controller emits a positive pulse.
46	Impulse controller voltage -	The corresponding output relay is accessed when the voltage impulse controller emits a negative pulse.
47	Impulse controller frequency +	The corresponding output relay is accessed when the frequency impulse controller emits a positive pulse.
48	Impulse controller frequency -	The corresponding output relay is accessed when the frequency impulse controller emits a negative pulse.
49	Input DI1 - TML2	The corresponding output relay is activated, when the digital input DI1 at terminal 2 (<i>see chap. 4.2.1 – Connection Diagram</i>) is closed.
50	Input DI2 - TML3	The corresponding output relay is activated, when the digital input DI2 at terminal 3 (<i>see chap. 4.2.1 – Connection Diagram</i>) is closed.
51	Input DI3 - TML4	The corresponding output relay is activated, when the digital input DI3 at terminal 4 (<i>see chap. 4.2.1 – Connection Diagram</i>) is closed.
52	Error reset	The corresponding output relay is energised when the manual error reset function via digital input or Enter button is activated (<i>see chap. 11.1</i>).
53	Language switching	The associated output relay is energised when the language switching via digital input is activated (<i>see chap. 11.1</i>).
54	Show synchronoscope	The associated output relay is energised when the displaying of synchronoscope is activated via digital input (<i>see chap. 11.1</i>).
55	Block all triggerings	The corresponding output relay is energised when the input function 'Block all triggerings' is activated (<i>see chap. 11.1</i>).
56	Lock 1	The corresponding output relay is energised when the input function 'Lock 1' is activated (<i>see chap. 11.1</i>).
57	Lock 2	The corresponding output relay is energised when the input function 'Lock 2' is activated (<i>see chap. 11.1</i>).

Synchronising Device SYR 2

Description

No.	Function	Description
58	Lock 3	The corresponding output relay is energised when the input function 'Lock 3' is activated (<i>see chap. 11.1</i>).
59	Acknowledgement DO1	The corresponding output relay is energised, if the function 'Acknowledgement DO1' via digital input (<i>see chap. 11.1</i>) is activated.
60	Acknowledgement DO2	The corresponding output relay is energised, if the function 'Acknowledgement DO2' via digital input (<i>see chap. 11.1</i>) is activated.
61	Acknowledgement DO3	The corresponding output relay is energised, if the function 'Acknowledgement DO3' via digital input (<i>see chap. 11.1</i>) is activated.
62	Acknowledgement DO4	The corresponding output relay is energised, if the function 'Acknowledgement DO4' via digital input (<i>see chap. 11.1</i>) is activated.
63	Acknowledgement DO5	The corresponding output relay is energised, if the function 'Acknowledgement DO5' via digital input (<i>see chap. 11.1</i>) is activated.
64	Acknowledgement DO6	The corresponding output relay is energised, if the function 'Acknowledgement DO6' via digital input (<i>see chap. 11.1</i>) is activated.
65	SYN clearance	The corresponding output relay is energised when the input function 'SYN clearance' (<i>see chap. 11.1</i>) is activated.
66	Isolated operation	The corresponding output relay is energised when the input function 'Isolated Operation' (<i>see chap. 11.1</i>) is activated.
67	External switching-on clearance	The corresponding output relay is energised when the input function 'external switching-on clearance' (<i>see chap. 11.1</i>) is activated.
68	Release delta-f	The corresponding output relay is energised when the input function 'clearance delta-f' (<i>see chap. 11.1</i>) is activated.
69	PSP 2 selected	The associated output relay is energised when the input function 'PSP choice 2' (<i>see chap. 11.1</i>) is activated.
70	PSP 3 selected	The associated output relay is energised when the input function 'PSP choice 3' (<i>see chap. 11.1</i>) is activated.
71	PSP 4 selected	The associated output relay is energised when the input function 'PSP choice 4' (<i>see chap. 11.1</i>) is activated.
75	PSP bit 1 selected	The associated output relay is energised when the input function 'PSP choice bit 1' (<i>see chap. 11.1</i>) is activated.
76	PSP bit 2 selected	The associated output relay is energised when the input function 'Psp choice bit 2' (<i>see chap. 11.1</i>) is activated.
77	PSP bit 3 selected	The associated output relay is energised when the input function 'PSP choice bit 3' (<i>see chap. 11.1</i>) is activated.
78	El. potentiometer U reset	The corresponding output relay is energised when the input function 'electronic potentiometer U reset' (<i>see chap. 11.1</i>) is activated.
79	El. potentiometer f reset	The corresponding output relay is energised when the input function 'electronic potentiometer f reset' (<i>see chap. 11.1</i>) is activated.
80	Voltage +	The corresponding output relay is energised when the input function 'control pulse voltage +' (<i>see chap. 11.1</i>) is activated.
81	Voltage -	The corresponding output relay is energised when the input function 'control pulse voltage -' (<i>see chap. 11.1</i>) is activated.
82	Frequency +	The corresponding output relay is energised when the input function 'control pulse frequency +' (<i>see chap. 11.1</i>) is activated.

Synchronising Device SYR 2

Description

No.	Function	Description
83	Frequency -	The corresponding output relay is energised when the input function 'control pulse frequency -' (<i>see chap. 11.1</i>) is activated.
84	Status relay DO1	The corresponding output relay is activated, when the output relay 1 is energised.
85	Status relay DO2	The corresponding output relay is activated, when the output relay 2 is energised.
86	Status relay DO3	The corresponding output relay is activated, when the output relay 3 is energised.
87	Status relay DO4	The corresponding output relay is activated, when the output relay 4 is energised.
88	Status relay DO5	The corresponding output relay is activated, when the output relay 5 is energised.
99	Status relay DO6	The corresponding output relay is activated, when the output relay 6 is energised.
90	Switching point 1	The corresponding output relay is activated, when the function 'switching point 1' (<i>see chap. 7.11</i>) has exceeded or undershot the set limit value and the delay time has elapsed.
91	Switching point 2	The corresponding output relay is activated, when the function 'switching point 2' (<i>see chap. 7.11</i>) has exceeded or undershot the set limit value and the delay time has elapsed.
92	Switching point 3	The corresponding output relay is activated, when the function 'switching point 3' (<i>see chap. 7.11</i>) has exceeded or undershot the set limit value and the delay time has elapsed.
93	Logic 1	The associated output relay is activated, if the function 'Logic 1' (<i>see chap. 13</i>) has the output value 'true'.
94	Logic 2	The associated output relay is activated, if the function 'Logic 2' (<i>see chap. 13</i>) has the output value 'true'.
95	Logic 3	The associated output relay is activated, if the function 'Logic 3' (<i>see chap. 13</i>) has the output value 'true'.
96	Logic 4	The associated output relay is activated, if the function 'Logic 4' (<i>see chap. 13</i>) has the output value 'true'.
97	Logic 5	The associated output relay is activated, if the function 'Logic 5' (<i>see chap. 13</i>) has the output value 'true'.
98	Timer 1	The associated output relay is activated, if the function 'Timer 1' (<i>see chap. 13</i>) has the output value 'true'.
99	Timer 2	The associated output relay is activated, if the function 'Timer 2' (<i>see chap. 13</i>) has the output value 'true'.
100	SYN Pulse	The corresponding output relay behaves as a SYN pulse relay according to the configuration.
101	Locking relay	The corresponding output relay behaves as a blocking relay according to the configuration.

Synchronising Device SYR 2

Description

12.2 Analogue Outputs (optionally)

The SYR2 is optionally available with two 0(2) ... 10 V analogue outputs, which can be assigned to various functions. Analogue output 1 is parameterisable via GV-2 as 0(4) ... 20 mA current output.

Function: A function, as described in the table below, can be assigned to the analogue output.

Working area: This option defines the limits of the analogue output. The following settings are available:

- 0 ... 10 V
- 2 ... 10 V
- 0 ... max. 10 V
- 2 ... max. 10 V
- 0 ... 20 mA (only analogue output 1)
- 2 ... 20 mA (only analogue output 1)
- 0 ... max. 20 mA (only analogue output 1)
- 2 ... max. 20 mA (only analogue output 1)

Start value: Specifies, at which percentage amount of the functional variable, the start value of the analogue output (0/2 V or 0/4 mA at xx% of the function variable).

End value: Specifies, at which percentage amount of the functional variable, the end value of the analogue output (10 V or 20 mA at xx% of the function variable).

Offset: This value is only active and accessible when the PID function is selected. The analog output is raised by the set offset (the offset so is added to the output value of the PID controller). This setting is necessary since the PID controller at a control difference = 0 also supplies an (internal) output signal of 0. The offset allows control in both directions without having to adjust the start and end values.

The reference potential of the two analogue outputs is terminal KL1.

The following functions can be assigned to the analogue outputs:

No.	Function	Description
0	Without Function	The output is not active
1	Mains voltage L1-N	Mains voltage L1 scaled in xx.x % of the nominal voltage.
2	Mains voltage L2-N	Mains voltage L2 scaled in xx.x % of the nominal voltage.
3	Mains voltage L3-N	Mains voltage L3 scaled in xx.x % of the nominal voltage.
4	Mains voltage average L1-N / L2-N / L3-N	Mean value of the mains neutral point voltages in xx.x % of the nominal voltages.
5	Mains voltage L1-L2	Mains voltage L1-L2 scaled in xx.x % of the nominal voltage.
6	Mains voltage L2-L3	Mains voltage L2-L3 scaled in xx.x % of the nominal voltage.
7	Mains voltage L3-L1	Mains voltage L3-L1 scaled in xx.x % of the nominal voltage.
8	Mains voltage average L12 / L23 / L31	Mean value of the mains external conductors in xx.x % of the nominal voltage.
9	Generator voltage L1-N	Generator voltage L1 scaled in xx.x % of the nominal voltage.
10	Generator voltage L2-N	Generator voltage L2 scaled in xx.x % of the nominal voltage.
11	Generator voltage L3-N	Generator voltage L3 scaled in xx.x % of the nominal voltage.
12	Generator voltage average L1-N / L2-N / L3-N	Mean value of the generator neutral point voltages in xx.x % of the nominal voltages.

Synchronising Device SYR 2

Description

No.	Function	Description
13	Generator voltage L1-L2	Generator voltage L1-L2 scaled in xx.x % of the nominal voltage.
14	Generator voltage L2-L3	Generator voltage L2-L3 scaled in xx.x % of the nominal value.
15	Generator voltage L3-L1	Generator voltage L3-L1 scaled in xx.x % of the nominal value.
16	Generator voltage average L12 / L23 / L31	Mean value of the generator external conductor voltages in xx.x % of the nominal voltages.
17	Mains frequency L1	Mains frequency L1 scaled in xxx.xx Cy.
18	Generator frequency L1	Generator frequency L1 scaled in xxx.xx Cy.
19	Electronic potentiometer voltage	The analogue output emits the value of the electronic potentiometer voltage.
20	Electronic potentiometer frequency	The analogue output emits the value of the electronic potentiometer frequency.
21	PID-T1 controller voltage	The analogue output emits the value of PID-T1 controller voltage.
22	PID-T1 controller voltage	The analogue output emits the value of PID-T1 controller frequency.


Synchronising Device SYR 2

Description

13 Logic Functions

The SYR2 is equipped with programmable logic modules. The following functions are available:

- AND gate
- OR gate
- Exclusive OR gate
- AND Not gate
- OR Not gate
- Exclusive Not OR gate
- Timer pick up delayed
- Timer drop out delayed




All logic and timer functions can be assigned to the fault message groups and to the collective fault. The available blocking functions are also available for all logic and timer functions. Each input function is invertible.

For all logic and timer functions, the digital output functions (see *chap. 12.1 - Digital Outputs*) are available as input functions.

13.1 Output Logic Function on Digital Input Function

Each (virtual) output of the logic gates can be linked to an input function. The input function is then activated either via the digital input (if assigned) or via the output of the logic function.




In the example shown above, the output of the function 'Logic 1' is linked to the input function 'SYN enable'.

The input function 'SYN clearance' is activated via the output of the function 'Logic 1', if both, the digital output function 'Voltage generator OK' and the digital input DI1 are activated.

Synchronising Device SYR 2


Description

13.2 AND – Gate (1)




2 parameterisable inputs are logical AND linked.

13.3 OR – Gate (2)




2 parameterisable inputs are logical OR linked.

13.4 Exclusive OR – Gate (3)




2 parameterisable inputs are logical EXCLUSIVE OR linked.

13.5 AND-Not – Gate (4)




2 parameterisable inputs are logical AND NOT linked.

13.6 OR-Not – Gate (5)



2 parameterisable inputs are logical OR NOT linked.

13.7 Exklusiv Nicht-ODER – Gatter (6)



2 parameterisable inputs are logical EXCLUSIVE NOT OR linked.

Synchronising Device SYR 2

Description

13.8 Timer pick up delayed



switch on delay time

If the input signal is active, the output of the timer only switches after the set delay time has elapsed (*example figured left: 1,0 s*).

13.9 Timer abfallverzögert



switch off delay time

After drop out of the input signal, the output of the timer switches off only after the set delay time has elapsed (*example figured left: 1,0 s*)

13.10 Fault Message Assignment

- ☐ central fault
- ☐ central fault 1
- ☐ central fault 2

All logic and timer functions can be individually assigned to the 'collective fault', 'collective fault 1', 'collective fault 2' and the fault message groups U, I, F, and P.

13.11 Locking Functions and Auto Reset

automatic reset ☒

disable limit value

☐ time lock ☐ trip lock 1 ☐ trip lock 2 ☒ disable all

For all logic and timer functions, the fault messaging behavior can be set to auto-reset and the available Locking functions can be activated in order to suppress a fault message if necessary. The logic and timer functions are executed independently of this.

Synchronising Device SYR 2


Description

14 Technical Data



Assembly and putting into operation only by trained professionals
Connecting in compliance with VDE 0160

Auxiliary voltage (operating voltage)	- 24 V DC (18 – 36 V) - 230 V AC / 50 cy (180 – 265 V)
Power consumption	approx. 4 W at 24 V DC approx. 6 VA at 230 V AC
Digital inputs	LowActive contact voltage 12 V DC, 5 mA, opto-decoupled), cables not longer than 3 m.
Relay outputs	230 V / 50 cy / 2 A (potential free) - 1 neutral changeover contact (DO5) - 1 neural normally open contact (DO6) - 4 normally open contacts with common root (DO1 – DO4)
Analogue outputs (optionally)	0 ... 10 V DC +/- 0.05 V max. 10.5 V 0 ... 20 mA +/- 0.1 mA max. 21 mA $R_{Load} \geq 1 \text{ k}\Omega$ (voltage output) / $R_{Load} \leq 400 \Omega$ (current output)
Measuring range voltage	approx. 20 up to 280 / 480 V AC, class 0.2 tolerance < 0,1 % of end value (270 / 480 V AC)
Measuring range frequency	15.0 cy up to 100.0 cy starts with approx. 10 V L-N / adjustable in 0.01 cy steps, repeat accuracy < 0.01 cy
Climatic conditions:	according to DIN EN 60255-1 (09-2010)
Ambient temperature in operation transport and storage	-20 °C ... +55 °C -25 °C ... +55 °C
Housing	top-hat rail mounting 35 mm (DIN EN 60715) dimensions: W / H / D: 100 x 75 x 110 mm



14.1 Triggering Values

	Setting range	Resolution	Repeatability	Minimum triggering delay
Over- / Undervoltage	10 up to 199 % nominal voltage	0,1 %	< 0,1 %	< 60 ms, typ. 48 ms
Over- / Underfrequency	35.0 ... 65.0 cy	0,01 cy	< 0,01 cy	< 60 ms, typ. 48 ms
Vector shift	5 ... 45°	0,1°	0,2°	60 ... 80 ms

Synchronising Device SYR 2

Description

Annex 1 Parameter Groups

Annex 1.1 Configuration (Konfig. / Config – Group 1)

The parameter group 1 contains two parameters per subgroup (*refer to chap. 6.6*). The following settings are available:

Parameter		Description	Setting range	Default
1.6.1 1.6.2	PIN protection	4-digit PIN Code activating of input PIN protection	0001 ... 9999 1 / 0 (on / off)	0001 off (0)
1.9.1 1.9.2	Nominal voltage	Nominal voltage of the plant in xxxxxx.x Volt (conductor voltage at 3-wire systems; string voltage at 3-wire+N systems) without function	50.0 ... 99,999.9 V -	230.9 V 0
1.12.1 1.12.2	Nominal frequency	Nominal frequency of the plant, 50 or 60 cy without function	0 / 255 (50 / 60 cy) -	50 cy (0) 0
1.13.1 1.13.2	Primary voltage mains	Mains primary voltage of the plant in xxxxxx Volt without function	1 ... 100,000 V -	231 V 0
1.14.1 1.14.2	Secondary voltage mains	Mains secondary voltage of the plant in xxxxxx Volt without function	1 ... 100,000 V -	231 V 0
1.15.1 1.15.2	Kind of grid	3-wire system or 3-wire+N (4-wire-) system without function	0 / 255 (3- / 4-LN) -	3-LN (0) 0
1.16.1 1.16.2	First error display	Activating of first error display only (<i>see chap. 7.8.7</i>) without function	255 / 0 (on / off) -	off (0) 0
1.17.1 1.17.2	Display format	Displaying of voltage values (<i>see chap. 6.3</i>) without function	1 ... 5 (xx.x V - xxx kV) -	auto V (0) 0
1.18.1 1.18.2	Standard display	Displaying of absolute or relative values without function	1 / 2 (abs. / rel.) -	U-bar (64) 0
1.19.1 1.19.2	View reset time	Switching back to standard display in x sec. without function	0 ... 600 sec. -	60 sec. 0
1.20.1 1.20.2	Brightness max.	Maximum brightness of the lighting in % without function	50 ... 100 % -	100 % 0
1.21.1 1.21.2	Brightness min.	Minimum brightness of the lighting in % without function	0 ... 50 % -	10 % 0
1.22.1 1.22.2	Screensaver time	Time until activating brightness min. in x sec. without function	0 ... 600 sec. -	60 sec. 0
1.23.1 1.23.2	Analogue output	Activating of functions for analogue output (required for devices with analogue output!) without function	255 / 0 (on / off) -	off (0) 0
1.25.1 1.25.2	Primary voltage generator	Plant primary voltage of the generator (for all PSP) in xxxxxx Volt without function	1 ... 100,000 V -	231 V 0
1.26.1 1.26.2	Secondary voltage generator PSP 1	Plant secondary voltage of the generator for PSP 1 in xxxxxx Volt without function	1 ... 100,000 V -	231 V 0
1.27.1 1.27.2	Secondary voltage generator PSP 2	Plant secondary voltage of the generator for PSP 2 in xxxxxx Volt without function	1 ... 100,000 V -	400 V 0
1.28.1 1.28.2	Secondary voltage generator PSP 3	Plant secondary voltage of the generator for PSP 3 in xxxxxx Volt without function	1 ... 100,000 V -	400 V 0

Synchronising Device SYR 2

Description

Parameter	Description	Setting range	Default
1.29.1 1.29.2	Secondary voltage generator PSP 4	Plant secondary voltage of the generator for PSP 4 in xxxxx Volt without function 1 ... 100.000 V -	400 V 0
1.33.1 1.33.2	Number of PSP	Number of deployed parallel switching points 1 ... 4	1

Annex 1.2 Limit Values (Grenzwerte / Limits – Group 4)

The parameter group 4 contains four parameters per subgroup (*refer to chap. 6.6*). The following settings are available:

Parameter	Description	Setting range	Default
4.1.1 4.1.2 4.1.3 4.1.6	Undervoltage mains	Trigger switching point in xx.x % Switch-back Hysteresis in xx.x % Triggering delay in xx.xx sec. Coding of fault message behaviour 10.0 ... 199.9 % 0.5 ... 50.0 % 0.05 ... 999.99 sec. (see chap. 6.6.3)	90.0 % 0.5 % 0.05 sec. activated / auto-reset (100000000001001)
4.2.1 4.2.2 4.2.3 4.2.6	Overvoltage mains	Trigger switching point in xx.x % Switch-back Hysteresis in xx.x % Triggering delay in xx.xx sec. Coding of fault message behaviour 10.0 ... 199.9 % 0.5 ... 50.0 % 0.05 ... 999.99 sec. (see chap. 6.6.3)	110.0 % 0.5 % 0.05 sec. activated / auto-reset (100000000001001)
4.3.1 4.3.2 4.3.3 4.3.6	Undervoltage generator	Trigger switching point in xx.x % Switch-back Hysteresis in xx.x % Triggering delay in xx.xx sec. Coding of fault message behaviour 10.0 ... 199.9 % 0.5 ... 50.0 % 0.05 ... 999.99 sec. (see chap. 6.6.3)	80.0 % 0.5 % 0.05 sec. activated / auto-reset (100000000001001)
4.4.1 4.4.2 4.4.3 4.4.6	Overvoltage generator	Trigger switching point in xx.x % Switch-back Hysteresis in xx.x % Triggering delay in xx.xx sec. Coding of fault message behaviour 10.0 ... 199.9 % 0.5 ... 50.0 % 0.05 ... 999.99 sec. (see chap. 6.6.3)	115.0 % 0.5 % 0.05 sec. activated / auto-reset (100000000001001)
4.5.1 4.5.2 4.5.3 4.5.6	Underfrequency mains	Trigger switching point in xx.xx cy Switch-back Hysteresis in x.xx cy Triggering delay in xx.xx sec. Coding 35.00 ... 75.00 cy 0.02 ... 2.00 cy 0.05 ... 999.99 sec. (see chap. 6.6.3)	49.50 Cy 0.10 Cy 0.05 sec. activated / auto-reset (100000000001001)
4.6.1 4.6.2 4.6.3 4.6.6	Overfrequency mains	Trigger switching point in xx.xx cy Switch-back Hysteresis in x.xx cy Triggering delay in xx.xx sec. Coding 35.00 ... 75.00 cy 0.02 ... 2.00 cy 0.05 ... 999.99 sec. (see chap. 6.6.3)	50.05 Cy 0.5 Cy 0.05 sec. activated / auto-reset (100000000001001)
4.7.1 4.7.2 4.7.3 4.7.6	Underfrequency generator	Trigger switching point in xx.xx cy Switch-back Hysteresis in x.xx cy Triggering delay in xx.xx sec. Coding 35.00 ... 75.00 cy 0.02 ... 2.00 cy 0.05 ... 999.99 sec. (see chap. 6.6.3)	47.50 Cy 0.50 Cy 0.05 sec. activated / auto-reset (100000000001001)
4.8.1 4.8.2 4.8.3 4.8.6	Overfrequency generator	Trigger switching point in xx.xx cy Switch-back Hysteresis in x.xx cy Triggering delay in xx.xx sec. Coding 35.00 ... 75.00 cy 0.02 ... 2.00 cy 0.05 ... 999.99 sec. (see chap. 6.6.3)	51.50 Cy 0.50 Cy 0.05 sec. activated / auto-reset (100000000001001)
4.9.1 4.9.3 4.9.6	Vector shift mains	Trigger switching point in xx.x ° Function (see chap. 7.9.7) Coding 5,0 ... 45,0 ° 0 ... 5 (see chap. 7.9.7) (see chap. 6.6.3)	8,0 ° L1+L2+L3 (4) activated / auto-reset (100000000001001)
4.11.1 4.11.3 4.11.6	ROCOF mains	Trigger switching point in x.xx Cy/s Triggering delay in xx.xx sec. Coding 0.01 ... 10.00 cy/s 0.05 ... 999.99 sec. (see chap. 6.6.3)	0.10 Cy/s 1.00 sec. deactivated (0100100000001001)

Synchronising Device SYR 2

Description

Parameter	Description	Setting range	Default
4.13.1 4.13.2 4.13.3 4.13.6	Angle mains	Trigger switching point in xxx ° Switch-back Hysteresis in xx ° Triggering delay in xx.xx sec. Coding 1 ... 60 ° 1 ... 20 ° 0.05 ... 999.99 sec. (see chap. 6.6.3)	10 ° 1 ° 1.00 sec. deactivated (0100100000001011)
4.14.1 4.14.2 4.14.3 4.14.6	Angle generator	Trigger switching point in xxx ° Switch-back Hysteresis in xx ° Triggering delay in xx.xx sec. Coding 1 ... 60 ° 1 ... 20 ° 0.05 ... 999.99 sec. (see chap. 6.6.3)	20 ° 1 ° 1.00 sec. deactivated (0100100000001011)
4.15.1 4.15.2 4.15.3 4.15.6	Voltage asymmetry mains	Trigger switching point in xx.x % Switch-back Hysteresis in xx.x % Triggering delay in xx.xx sec. Coding 1.0 ... 100.0 % 0.5 ... 50.0 % 0.05 ... 999.99 sec. (see chap. 6.6.3)	10.0 % 1.0 % 0.05 sec. deactivated (0100100000001011)
4.16.1 4.16.2 4.16.3 4.16.6	Voltage asymmetry generator	Trigger switching point in xx.x % Switch-back Hysteresis in xx.x % Triggering delay in xx.xx sec. Coding 1.0 ... 100.0 % 0.5 ... 50.0 % 0.05 ... 999.99 sec. (see chap. 6.6.3)	10.0 % 1.0 % 0.05 sec. deactivated (0100100000001011)
4.17.1 4.17.6	Rotary field monitoring mains / generator	Rotary field right or left Coding 1 / 0 (left / right) (see chap. 6.6.3)	right (0) activated (1000000000001001)
4.19.1 4.19.2 4.19.3 4.19.6	Voltage quality mains	Trigger switching point in xx.x % Switch-back Hysteresis in xx.x % Triggering delay in xx.xx sec. Coding 110.0 ... 115.0 % 0.5 ... 3.0 % 600 sec. (see chap. 6.6.3)	110.0 % 1.0 % 600 sec. deactivated (0100100000001011)
4.20.1 4.20.2 4.20.3 4.20.6	Mean value deviation mains	Trigger switching point in xx.x % Switch-back Hysteresis in xx.x % Triggering delay in xx.xx sec. Coding 1.0 ... 100.0 % 0.5 ... 50.0 % 0.05 ... 999.99 sec. (see chap. 6.6.3)	90.0 % 1.0 % 1.00 sec. deactivated (0000100000001011)
4.21.1 4.21.2 4.21.3 4.21.6	Mean value deviation generator	Trigger switching point in xx.x % Switch-back Hysteresis in xx.x % Triggering delay in xx.xx sec. Coding 1.0 ... 100.0 % 0.5 ... 50.0 % 0.05 ... 999.99 sec. (see chap. 6.6.3)	90.0 % 1.0 % 1.00 sec. deactivated (0000100000001011)
4.22.1 4.22.2 4.22.3 4.22.6	Slip	Trigger switching point in xx.xx Cy Switch-back Hysteresis in xx.xx Cy Triggering delay in xx.xx sec. Coding 0.01 ... 50.00 cy 0.02 ... 2.00 cy 0.05 ... 999.99 sec. (see chap. 6.6.3)	2.00 Cy 0.02 1.00 sec. deactivated (0100100011110001)
4.23.1 4.23.2 4.23.3 4.23.6	Switching-on voltage	Trigger switching point in xx.x % Switch-back Hysteresis in xx.x % Triggering delay in xx.xx sec. Coding 0.0 ... 150.0 % 0.5 ... 50.0 % 0.05 ... 999.99 s (see chap. 6.6.3)	80.0 % 5.0 % 0.05 s (1001100000111001)
4.24.1 4.24.2 4.24.3 4.24.6	Switching-on frequency	Trigger switching point in xx.xx Cy Switch-back Hysteresis in xx.xx Cy Triggering delay in xx.xx sec. Coding 35.00 ... 75.00 cy 0.02 ... 2.00 cy 0.05 ... 999.99 s (see chap. 6.6.3)	48.00 Cy 0.20 Cy 0.05 s (1001100000111001)
4.25.1 4.25.2 4.25.3 4.25.6	Sync pulse monitoring	Trigger switching point in seconds Coding 0 ... 200 s	200 s (1101100000011001)
4.26.1 4.26.2 4.26.3 4.26.6	Release monitoring	Trigger switching point in seconds Coding 0 ... 200 s	200 s (1101100000011001)

Synchronising Device SYR 2

Description

Parameter	Description	Setting range	Default
4.27.1 4.27.2 4.27.3 4.27.7	Switching point 1 Trigger switching point in xx.x % Switch-back Hysteresis in xx.x % Triggering delay in xx.xx sec. Coding	0.1 ... 199.0 % 0.5 ... 3.0 % 600 sec. (see chap. 6.6.3)	100.0 % 1.0 % 1 sec. 0 (without function)
4.28.1 4.28.2 4.28.3 4.28.7	Switching point 2 Trigger switching point in xx.x % Switch-back Hysteresis in xx.x % Triggering delay in xx.xx sec. Coding	0.1 ... 199.0 % 0.5 ... 3.0 % 600 sec. (see chap. 6.6.3)	100.0 % 1.0 % 1 sec. 0 (without function)
4.29.1 4.29.2 4.29.3 4.29.7	Switching point 3 Trigger switching point in xx.x % Switch-back Hysteresis in xx.x % Triggering delay in xx.xx sec. Coding	0.1 ... 199.0 % 0.5 ... 3.0 % 600 sec. (see chap. 6.6.3)	100.0 % 1.0 % 1 sec. 0 (without function)

Annex 1.3 Analogue Outputs

Parameter	Description	Setting range	Default
5.1.1 5.1.2 5.1.3 5.1.5	Analogue 1 Function assignment Start value (at 0 resp. 2 V) End value (at 10 V) Working range Offset	0 .. 22 (see chap. 12.2) -150.0 ... 150.0 % -150.0 ... 150.0 % 0 .. 9 (see chap. 12.2) 0.00 ... 10.00 V	0 (0 .. 10 V) 0.0 % 100.0 % 0 (without function) 0.00 V
5.2.1 5.2.2 5.2.3 5.2.5	Analogue 2 Function assignment Start value (at 0 resp. 2 V) End value (at 10 V) Working range Offset	0 .. 22 (see chap. 12.2) -150.0 ... 150.0 % -150.0 ... 150.0 % 0 .. 9 (see chap. 12.2) 0.00 ... 10.00 V	0 (0 .. 10 V) 0.0 % 100.0 % 0 (without function) 0.00 V

Annex 1.4 Digital Outputs (Digi. Ausg. / OUT – Group 6)

The parameter group 6 contains three parameters per subgroup (refer to chap. 6.6.2). The following settings are available:

Parameter	Description	Setting range	Default
6.1.1 6.1.2 6.1.3	DO1 / Relay 1, terminal KL 9 Function Switching behaviour Pulse duration (min.)	0 ... 101 (see chap. 12.1) 1 / 0 (quiescent- / working current) 0.1 ... 6,000.0 sec.	Pulse voltage - (46) Working current (0) 2.0 sec.
6.2.1 6.2.2 6.2.3	DO2 / Relay 2, terminal KL 10 Function Switching behaviour Pulse duration (min.)	0 ... 101 (see chap. 12.1) 1 / 0 (quiescent- / working current) 0.1 ... 6,000.0 sec.	Pulse voltage + (45) Working current (0) 2.0 sec.
6.3.1 6.3.2 6.3.3	DO3 / Relay 3, terminal KL 11 Function Switching behaviour Pulse duration (min.)	0 ... 101 (see chap. 12.1) 1 / 0 (quiescent- / working current) 0.1 ... 6,000.0 sec.	Pulse frequency - (48) Working current (0) 2.0 sec.
6.4.1 6.4.2 6.4.3	DO4 / Relay 4, terminal KL 12 Function Switching behaviour Pulse duration (min.)	0 ... 101 (see chap. 12.1) 1 / 0 (quiescent- / working current) 0.1 ... 6,000.0 sec.	Pulse frequency + (47) Working current (0) 2.0 sec.
6.5.1 6.5.2 6.5.3	DO5 / Relay 5, term. KL 13-15 Function Switching behaviour Pulse duration (min.)	0 ... 101 (see chap. 12.1) 1 / 0 (quiescent- / working current) 0.1 ... 6,000.0 sec.	ready for operation (1) Working current (0) 2.0 sec.
6.6.1 6.6.2 6.6.3	DO6 / Relay 6, term. KL 26 / 27 Function Switching behaviour Pulse duration (min.)	0 ... 101 (see chap. 12.1) 1 / 0 (quiescent- / working current) 0.1 ... 6,000.0 sec.	Sync pulse (100) Working current (0) 2.0 sec.

Synchronising Device SYR 2

Description

Annex 1.5 Digital Inputs (Digi. Eing. / IN – Group 7)

The parameter group 7 contains two parameters per subgroup (*refer to chap. 6.6.2*). The following settings are available:

Parameter	Description	Setting range	Default
7.1.1 7.1.2	DI1 / terminal KL 2 Function Switching behaviour	0 .. 40 (<i>see chap. 11.1</i>) 1 / 0 (quiescent- / working current)	SYN clearance (20) working current (0)
7.1.1 7.1.2	DI2 / terminal KL 3 Function Switching behaviour	0 .. 40 (<i>see chap. 11.1</i>) 1 / 0 (quiescent- / working current)	Isolated operation (21) working current (0)
7.1.1 7.1.2	DI3 / terminal KL 4 Function Switching behaviour	0 .. 40 (<i>see chap. 11.1</i>) 1 / 0 (quiescent- / working current)	Error reset (5) working current (0)

Annex 1.6 Logic Functions (Logik – Group 10)

The parameter group 10 contains six respectively five parameters per subgroup (*refer to chap. 13*). The following settings are available:

Parameter	Description	Setting range	Default
11.1.1 11.1.2 11.1.3 11.1.4 11.1.5 11.1.7 11.1.8	Logic 1 Function E1 1 / 0 (inverted / normally) Function E2 1 / 0 (inverted / normally) Logic function Coding of fault message behaviour Internal assignment	0 ... 47 (<i>see chap. 11.1</i>) 0 or 1 0 ... 47 (<i>see chap. 11.1</i>) 0 or 1 0 ... 6 (<i>see chap. 13</i>) (<i>see chap. 6.6.3</i>) 0 ... 15 (<i>see chap. 11.1</i>)	0 (without Function) 0 (normally) 0 (without Function) 0 (normally) 0 (without Function) auto reset (1000000000001000) 0
11.2.1 11.2.2 11.2.3 11.2.4 11.2.5 11.2.7 11.2.8	Logic 2 Function E1 1 / 0 (inverted / normally) Function E2 1 / 0 (inverted / normally) Logic function Coding of fault message behaviour Internal assignment	0 ... 47 (<i>see chap. 11.1</i>) 0 or 1 0 ... 47 (<i>see chap. 11.1</i>) 0 or 1 0 ... 6 (<i>see chap. 13</i>) (<i>see chap. 6.6.3</i>) 0 ... 15 (<i>see chap. 11.1</i>)	0 (without Function) 0 (normally) 0 (without Function) 0 (normally) 0 (without Function) auto reset (1000000000001000) 0
11.3.1 11.3.2 11.3.3 11.3.4 11.3.5 11.3.7 11.3.8	Logic 3 Function E1 1 / 0 (inverted / normally) Function E2 1 / 0 (inverted / normally) Logic function Coding of fault message behaviour Internal assignment	0 ... 47 (<i>see chap. 11.1</i>) 0 or 1 0 ... 47 (<i>see chap. 11.1</i>) 0 or 1 0 ... 6 (<i>see chap. 13</i>) (<i>see chap. 6.6.3</i>) 0 ... 15 (<i>see chap. 11.1</i>)	0 (without Function) 0 (normally) 0 (without Function) 0 (normally) 0 (without Function) auto reset (1000000000001000) 0
11.4.1 11.4.2 11.4.3 11.4.4 11.4.5 11.4.7 11.4.8	Logic 4 Function E1 1 / 0 (inverted / normally) Function E2 1 / 0 (inverted / normally) Logic function Coding of fault message behaviour Internal assignment	0 ... 47 (<i>see chap. 11.1</i>) 0 or 1 0 ... 47 (<i>see chap. 11.1</i>) 0 or 1 0 ... 6 (<i>see chap. 13</i>) (<i>see chap. 6.6.3</i>) 0 ... 15 (<i>see chap. 11.1</i>)	0 (without Function) 0 (normally) 0 (without Function) 0 (normally) 0 (without Function) auto reset (1000000000001000) 0
11.5.1 11.5.2 11.5.3 11.5.4 11.5.5 11.5.7 11.5.8	Logic 5 Function E1 1 / 0 (inverted / normally) Function E2 1 / 0 (inverted / normally) Logic function Coding of fault message behaviour Internal assignment	0 ... 47 (<i>see chap. 11.1</i>) 0 or 1 0 ... 47 (<i>see chap. 11.1</i>) 0 or 1 0 ... 6 (<i>see chap. 13</i>) (<i>see chap. 6.6.3</i>) 0 ... 15 (<i>see chap. 11.1</i>)	0 (without Function) 0 (normally) 0 (without Function) 0 (normally) 0 (without Function) auto reset (1000000000001000) 0
11.6.1 11.6.2 11.6.5 11.6.6 11.6.7 11.6.8	Timer 1 Function input 1 / 0 (inverted / normally) Timer function (pick-up/drop-out delay) Timer duration Coding of fault message behaviour Internal assignment	0 ... 47 (<i>see chap. 11.1</i>) 0 or 1 0 or 1 (<i>see chap. 13</i>) 0 ... 6.000,0 sec. (<i>see chap. 6.6.3</i>) 0 ... 15 (<i>see chap. 11.1</i>)	0 (without Function) 0 (normally) 1 (pick-up delay) 1,0 sec. auto reset (1000100000001000) 0

Synchronising Device SYR 2

Description

Parameter	Description	Setting range	Default
11.7.1 11.7.2 11.7.5 11.7.6 11.7.7 11.7.8	Timer 2 Function input 1 / 0 (inverted / normally) Timer function (pick-up/drop-out delay) Timer duration Coding of fault message behaviour Internal assignment	0 ... 47 (see chap. 11.1) 0 or 1 0 or 1 (see chap. 13) 0 ... 6.000,0 sec. (see chap. 6.6.3) 0 ... 15 (see chap. 11.1)	0 (without Function) 0 (normally) 1 (pick-up delay) 1,0 sec. auto reset (1000100000001000) 0

Annex 1.7 Syn (SYN – Group 11)

Parameter	Description	Setting range	Default
11.3.1	Syn Delta Umax PSP1	Syn delta maximum voltage	0.0 ... 150.0 % 4.0 %
11.4.1	Target pt. freq. PSP1	Target point of frequency regulation	0.01 ... 15.00 cy 0.05 cy
11.5.1	Syn Delta fmax PSP1	Syn delta maximum frequency	0.01 ... 1.00 cy 0.10 cy
11.6.1	Syn Pulse Duration PSP1	Duration of the sync impulse	0.0 ... 100.0 s 1.0 s
11.7.1	Syn Delay Time PSP1	Time delay for the sync clearance	1 ... 25 s 2 s
11.8.1	Syn Lead Time PSP1	Lead time for the sync impulse	0 ... 1000 ms 100 ms
11.9.1	Syn Integ. Time Freq PSP1	Sync integrating time for frequency	1 ... 100 periods 5 per.
11.10.1	Block Delta Umax PSP1	Locking delta maximum voltage	0.0 ... 15 % 5 %
11.11.1	Block Delta fmax PSP1	Locking delta maximum frequency	0.01 ... 1.00 cy 0.50 cy
11.11.1	Block Delta Phi max PSP1	Locking delta phi maximum	0 ... 30° 10°
11.12.1 11.12.2	Isolated Operation Nominal Voltage PSP1	Nominal voltage isolated operation Deviating nominal voltage	0 ... 150 % 0 (no) / 255 (yes) 100 % no (0)
11.13.1 11.13.2	Isolated Operation Nominal Frequency PSP1	Nominal frequency Isolated mode Deviating nominal frequency	30 ... 75 cy 0 (no) / 255 (yes) 50 Cy no (0)
11.18.1	Syn Delta Umax PSP2	Syn delta maximum voltage	0.0 ... 150.0 % 4.0 %
11.19.1 11.19.2	Target pt. freq. PSP2	Target point of frequency regulation Frequency deviating from PSP 1	0.01 ... 15.00 cy 0 (no) / 255 (yes) 0.05 cy 0
11.20.1	Syn Delta fmax PSP2	Syn delta maximum frequency	0.01 ... 1.00 Cy 0.10 cy
11.21.1 11.21.2	Syn Pulse Duration PSP2	Duration of the sync impulse Time deviating from PSP 1	0.0 ... 100.0 s 0 (no) / 255 (yes) 1.0 s 0
11.22.1	Syn Delay Time PSP2	Time delay for the sync clearance	1 ... 25 s 2 s
11.23.1	Syn Lead Time PSP2	Lead time for the sync impulse	0 ... 1000 ms 100 ms
11.24.1	Syn Integ. Time Freq PSP2	Sync integrating time for frequency	1 ... 100 periods 5 per.
11.25.1 11.25.2	Block Delta Umax PSP2	Locking delta maximum voltage Deviating from PSP 1	0.0 ... 15.0 % 0 (no) / 255 (yes) 5.0 % 0
11.26.1 11.26.2	Block Delta fmax PSP2	Locking delta maximum frequency Deviating from PSP 1	0.01 ... 1.00 cy 0 (no) / 255 (yes) 0.50 cy 0
11.27.1 11.27.2	Block Delta Phi max PSP2	Locking delta phi maximum Deviating from von PSP 1	0 ... 30° 0 (no) / 255 (yes) 10° 0
11.28.1 11.28.2	Isolated Operation Nominal Voltage PSP2	Nominal voltage for isolated mode Deviating from nominal voltage	0 ... 150 % 0 (no) / 255 (yes) 100 % 0
11.29.1 11.29.2	Isolated Operation Nominal Frequency PSP2	Nominal frequency for Isolated mode operation Deviating from nominal frequency	30 ... 75 cy 0 (no) / 255 (yes) 50 cy 0

Synchronising Device SYR 2

Description

Parameter		Description	Setting range	Default
11.33.1	Syn Delta Umax PSP3	Syn delta maximum voltage	0.0 ... 150.0 %	4.0 %
11.34.1 11.34.2	Target pt. freq. PSP3	Target point of frequency regulation Frequency deviating from PSP 1	0.01 ... 15.00 cy 0 (no) / 255 (yes)	0.05 cy 0
11.35.1	Syn Delta fmax PSP3	Syn delta maximum frequency	0.01 ... 1.00 cy	0.10 cy
11.36.1 11.36.2	Syn Pulse Duration PSP3	Duration of the sync impulse Time deviating from PSP 1	0.0 ... 100.0 s 0 (no) / 255 (yes)	1.0 s 0
11.37.1	Syn Delay Time PSP3	Time delay for the sync clearance	1 ... 25 s	2 s
11.38.1	Syn Lead Time PSP3	Lead time for the sync impulse	0 ... 1000 ms	100 ms
11.39.1	Syn Integ. Time Freq PSP3	Sync integrating time for frequency	1 ... 100 periods	5 per.
11.40.1 11.40.2	Block Delta Umax PSP3	Locking delta maximum voltage Deviating from PSP 1	0.0 ... 15.0 % 0 (no) / 255 (yes)	5.0 % 0
11.41.1 11.41.2	Block Delta fmax PSP3	Locking delta maximum frequency Deviating from PSP 1	0.01 ... 1.00 cy 0 (no) / 255 (yes)	0.50 cy 0
11.42.1 11.42.2	Block Delta Phi max PSP3	Locking delta phi maximum Deviating from von PSP 1	0 ... 30° 0 (no) / 255 (yes)	10° 0
11.43.1 11.43.2	Isolated Operation Nominal Voltage PSP3	Nominal voltage isolated mode Deviating nominal voltage	0 ... 150 % 0 (no) / 255 (yes)	100 % 0
11.44.1 11.44.2	Isolated Operation Nominal Frequency PSP3	Nominal frequency isolated mode Deviating nominal frequency	30 ... 75 cy 0 (no) / 255 (yes)	50 cy 0
11.48.1	Syn Delta Umax PSP4	Syn delta maximum voltage	0.0 ... 150.0 %	4.0 %
11.49.1 11.49.2	Target pt. freq. PSP4	Target point of frequency regulation Frequency deviating from PSP 1	0.01 ... 15.00 cy 0 (no) / 255 (yes)	0.05 cy 0
11.50.1	Syn Delta fmax PSP4	Syn delta maximum frequency	0.01 ... 1.00 cy	0.10 cy
11.51.1 11.51.2	Syn Pulse Duration PSP4	Duration of the sync impulse Time deviating from PSP 1	0.0 ... 100.0 s 0 (no) / 255 (yes)	1.0 s 0
11.52.1	Syn Delay Time PSP4	Time delay for the sync clearance	1 ... 25 s	2 s
11.53.1	Syn Lead Time PSP4	Lead time for the sync impulse	0 ... 1000 ms	100 ms
11.54.1	Syn Integ. Time Freq PSP4	Sync integrating time for frequency	1 ... 100 periods	5 per.
11.55.1 11.55.2	Block Delta Umax PSP4	Locking delta maximum voltage Deviating from PSP 1	0.0 ... 15.0 % 0 (no) / 255 (yes)	5.0 % 0
11.56.1 11.56.2	Block Delta fmax PSP4	Locking delta maximum frequency Deviating from PSP 1	0.01 ... 1.00 cy 0 (no) / 255 (yes)	0.50 cy 0
11.57.1 11.57.2	Block Delta Phi max PSP4	Locking delta phi maximum Deviating from von PSP 1	0 ... 30° 0 (no) / 255 (yes)	10° 0
11.58.1 11.58.2	Isolated Operation Nominal Voltage PSP4	Nominal voltage isolated mode Deviating nominal voltage	0 ... 150 % 0 (no) / 255 (yes)	100 % 0
11.59.1 11.59.2	Isolated Operation Nominal Frequency PSP4	Nominal frequency isolated mode Deviating nominal frequency	30 ... 75 cy 0 (no) / 255 (yes)	50 cy 0

Synchronising Device SYR 2

Description

Annex 1.8 PID-T1-, Pulse Controller and Electronic Potentiometers (Regler-Group 12)

The parameter group 12 contains up to eight parameters per subgroup (*refer to chap. 6.6.2*). The following settings are available:

Parameter	Description	Setting range	Default
12.2.2	PID voltage isolated / global PSP1	Delay time	0.0 ... 600.0
12.2.3		Ramp time	0.0 ... 600.0
12.2.4		Dead zone	0.0 ... 50.0 %
12.2.5		Amplification (Kp)	0.01 ... 99.99
12.2.6		Integration time (Tn)	0.0 ... 999.9 sec.
12.2.7		Derivative time (Tv)	0.0 ... 99.9 sec.
12.2.8		Reset time (T1)	0.0 ... 99.9 sec.
12.2.10		global / operating mode depended	0 (OM depended) / 255 (global)
12.3.2	PID frequency isolated / global PSP1	Delay time	0.0 ... 600.0
12.3.3		Ramp time	0.0 ... 600.0
12.3.4		Dead zone	0.0 ... 50.0 %
12.3.5		Amplification (Kp)	0.01 ... 99.99
12.3.6		Integration time (Tn)	0.0 ... 999.9 sec.
12.3.7		Derivative time (Tv)	0.0 ... 99.9 sec.
12.3.8		Reset time (T1)	0.0 ... 99.9 sec.
12.3.10		global / operating mode depended	0 (OM depended) / 255 (global)
12.4.2	PID voltage SYN PSP1	Delay time	0.0 ... 600.0
12.4.3		Ramp time	0.0 ... 600.0
12.4.4		Dead zone	0.0 ... 50.0 %
12.4.5		Amplification (Kp)	0.01 ... 99.99
12.4.6		Integration time (Tn)	0.0 ... 999.9 sec.
12.4.7		Derivative time (Tv)	0.0 ... 99.9 sec.
12.4.8		Reset time (T1)	0.0 ... 99.9 sec.
12.5.2	PID Frequency SYN PSP1	Delay time	0.0 ... 600.0
12.5.3		Ramp time	0.0 ... 600.0
12.5.4		Dead zone	0.0 ... 50.0 %
12.5.5		Amplification (Kp)	0.01 ... 99.99
12.5.6		Integration time (Tn)	0.0 ... 999.9 sec.
12.5.7		Derivative time (Tv)	0.0 ... 99.9 sec.
12.5.8		Reset time (T1)	0.0 ... 99.9 sec.
12.6.2	PID voltage mains parallel PSP1	Delay time	0.0 ... 600.0
12.6.3		Ramp time	0.0 ... 600.0
12.6.4		Dead zone	0.0 ... 50.0 %
12.6.5		Amplification (Kp)	0.01 ... 99.99
12.6.6		Integration time (Tn)	0.0 ... 999.9 sec.
12.6.7		Derivative time (Tv)	0.0 ... 99.9 sec.
12.6.8		Reset time (T1)	0.0 ... 99.9 sec.
12.7.2	PID Frequency mains parallel PSP1	Delay time	0.0 ... 600.0
12.7.3		Ramp time	0.0 ... 600.0
12.7.4		Dead zone	0.0 ... 50.0 %
12.7.5		Amplification (Kp)	0.01 ... 99.99
12.7.6		Integration time (Tn)	0.0 ... 999.9 sec.
12.7.7		Derivative time (Tv)	0.0 ... 99.9 sec.
12.7.8		Reset time (T1)	0.0 ... 99.9 sec.
12.8.2	IMP voltage isolated / global PSP1	Release delay time	0.0 ... 600.0
12.8.3		Modulation	0 (PWM) / 1 (PFM)
12.8.4		Dead zone	0.0 ... 50.0 %
12.8.5		Amplify (pulse / % / pulse / per.)	0.01 ... 99.99
12.8.6		Pulse duration / period duration	0.1 ... 999.9 sec.
12.8.10		global / operating mode depended	0 (OM depended) / 255 (global)
12.9.2	IMP frequency isolated / global PSP1	Release delay time	0.0 ... 600.0
12.9.3		Modulation	0 (PWM) / 1 (PFM)
12.9.4		Dead zone	0.0 ... 50.0 %
12.9.5		Amplify (pulse / % / pulse / per.)	0.01 ... 99.99
12.9.6		Pulse duration / period duration	0.1 ... 999.9 sec.
12.9.10		global / operating mode depended	0 (OM depended) / 255 (global)

Synchronising Device SYR 2

Description

Parameter		Description	Setting range	Default
12.10.2	IMP voltage SYN PSP1	Release delay time	0.0 ... 600.0	0.5 sec.
12.10.3		Modulation	0 (PWM) / 1 (PFM)	1
12.10.4		Dead zone	0.0 ... 50.0 %	1.0 %
12.10.5		Amplify (pulse / % / pulse / per.)	0.01 ... 99.99	0.5 sec.
12.10.6		Pulse duration / period duration	0.1 ... 999.9 sec.	0.1 sec.
12.11.2	IMP frequency SYN PSP1	Release delay time	0.0 ... 600.0	0.5 sec.
12.11.3		Modulation	0 (PWM) / 1 (PFM)	1
12.11.4		Dead zone	0.0 ... 50.0 %	0.1 %
12.11.5		Amplify (pulse / % / pulse / per.)	0.01 ... 99.99	0.5 sec.
12.11.6		Pulse duration / period duration	0.1 ... 999.9 sec.	0.1 sec.
12.12.2	IMP voltage mains parallel PSP1	Release delay time	0.0 ... 600.0	0.5 sec.
12.12.3		Modulation	0 (PWM) / 1 (PFM)	1
12.12.4		Dead zone	0.0 ... 50.0 %	1.0 %
12.12.5		Amplify (pulse / % / pulse / per.)	0.01 ... 99.99	0.5 sec.
12.12.6		Pulse duration / period duration	0.1 ... 999.9 sec.	0.1 sec.
12.13.2	IMP frequency mains parallel I PSP1	Release delay time	0.0 ... 600.0	0.5 sec.
12.13.3		Modulation	0 (PWM) / 1 (PFM)	1
12.13.4		Dead zone	0.0 ... 50.0 %	0.1 %
12.13.5		Amplify (pulse / % / pulse / per.)	0.01 ... 99.99	0.5 sec.
12.13.6		Pulse duration / period duration	0.1 ... 999.9 sec.	0.1 sec.
12.14.3	Electronic potentiometer Voltage isolated / global PSP1	Ramp	0.1 ... 250.0 s	10.0 s
12.14.5		Swing	0.01 ... 10.00 V	5.00 V
12.14.6		Offset	0.00 ... 10.00 V	5.00 V
12.14.10		global / operating mode depended	0 (OM depended) / 255 (global)	255
12.15.3	Electronic potentiometer Frequency isolated / global PSP1	Ramp	0.1 ... 250.0 s	10.0 s
12.15.5		Swing	0.01 ... 10.00 V	5.00 V
12.15.6		Offset	0.00 ... 10.00 V	5.00 V
12.15.10		global / operating mode depended	0 (OM depended) / 255 (global)	255
12.16.3	Electronic potentiometer Voltage SYN PSP1	Ramp	0.1 ... 250.0 s	10.0 s
12.16.5		Swing	0.01 ... 10.00 V	5.00 V
12.16.6		Offset	0.00 ... 10.00 V	5.00 V
12.17.3	Electronic potentiometer Frequency SYN PSP1	Ramp	0.1 ... 250.0 s	10.0 s
12.17.5		Swing	0.01 ... 10.00 V	5.00 V
12.17.6		Offset	0.00 ... 10.00 V	5.00 V
12.18.3	Electronic potentiometer Voltage mains parallel PSP1	Ramp	0.1 ... 250.0 s	10.0 s
12.18.5		Swing	0.01 ... 10.00 V	5.00 V
12.18.6		Offset	0.00 ... 10.00 V	5.00 V
12.19.3	Electronic potentiometer Frequency mains parallel PSP1	Ramp	0.1 ... 250.0 s	10.0 s
12.19.5		Swing	0.01 ... 10.00 V	5.00 V
12.19.6		Offset	0.00 ... 10.00 V	5.00 V
12.21.2	PID Voltage isolated / global PSP2	Delay time	0.0 ... 600.0	0.5 sec.
12.21.3		Ramp time	0.0 ... 600.0	0.0 sec.
12.21.4		Dead zone	0.0 ... 50.0 %	1.0 %
12.21.5		Amplification (Kp)	0.01 ... 99.99	0.10
12.21.6		Integration time (Tn)	0.0 ... 999.9 sec.	0.5 sec.
12.21.7		Derivative time (Tv)	0.0 ... 99.9 sec.	0.0 sec.
12.21.8		Reset time (T1)	0.0 ... 99.9 sec.	0.0 sec.
12.21.9		Deviating from PSP1	0 (as PSP1) / 255 (deviating)	0
12.21.10		global / operating mode depended	0 (OM depended) / 255 (global)	255
12.22.2	PID Frequency isolated / global PSP2	Delay time	0.0 ... 600.0	0.5 sec.
12.22.3		Ramp time	0.0 ... 600.0	0.0 sec.
12.22.4		Dead zone	0.0 ... 50.0 %	0.1 %
12.22.5		Amplification (Kp)	0.01 ... 99.99	0.10
12.22.6		Integration time (Tn)	0.0 ... 999.9 sec.	0.5 sec.
12.22.7		Derivative time (Tv)	0.0 ... 99.9 sec.	0.0 sec.
12.22.8		Reset time (T1)	0.0 ... 99.9 sec.	0.0 sec.
12.22.9		Deviating from PSP1	0 (as PSP1) / 255 (deviating)	0
12.22.10		global / operating mode depended	0 (OM depended) / 255 (global)	255

Synchronising Device SYR 2

Description

Parameter	Description	Setting range	Default
12.23.2	PID Voltage SYN PSP2	Delay time	0.0 ... 600.0
12.23.3		Ramp time	0.0 ... 600.0
12.23.4		Dead zone	0.0 ... 50.0 %
12.23.5		Amplification (Kp)	0.01 ... 99.99
12.23.6		Integration time (Tn)	0.0 ... 999.9 sec.
12.23.7		Derivative time (Tv)	0.0 ... 99.9 sec.
12.23.8		Reset time (T1)	0.0 ... 99.9 sec.
12.24.2	PID Frequency SYN PSP2	Delay time	0.0 ... 600.0
12.24.3		Ramp time	0.0 ... 600.0
12.24.4		Dead zone	0.0 ... 50.0 %
12.24.5		Amplification (Kp)	0.01 ... 99.99
12.24.6		Integration time (Tn)	0.0 ... 999.9 sec.
12.24.7		Derivative time (Tv)	0.0 ... 99.9 sec.
12.24.8		Reset time (T1)	0.0 ... 99.9 sec.
12.25.2	PID Voltage Mains parallel PSP2	Delay time	0.0 ... 600.0
12.25.3		Ramp time	0.0 ... 600.0
12.25.4		Dead zone	0.0 ... 50.0 %
12.25.5		Amplification (Kp)	0.01 ... 99.99
12.25.6		Integration time (Tn)	0.0 ... 999.9 sec.
12.25.7		Derivative time (Tv)	0.0 ... 99.9 sec.
12.25.8		Reset time (T1)	0.0 ... 99.9 sec.
12.26.2	PID Frequency Mains parallel PSP2	Delay time	0.0 ... 600.0
12.26.3		Ramp time	0.0 ... 600.0
12.26.4		Dead zone	0.0 ... 50.0 %
12.26.5		Amplification (Kp)	0.01 ... 99.99
12.26.6		Integration time (Tn)	0.0 ... 999.9 sec.
12.26.7		Derivative time (Tv)	0.0 ... 99.9 sec.
12.26.8		Reset time (T1)	0.0 ... 99.9 sec.
12.27.2	IMP Voltage isolated / global PSP2	Release delay	0.0 ... 600.0
12.27.3		Modulation	0 (PWM) / 1 (PFM)
12.27.4		Dead zone	0.0 ... 50.0 %
12.27.5		Amplify (pulse / % / pulse / per.)	0.01 ... 99.99
12.27.6		Pulse duration / period duration	0.1 ... 999.9 sec.
12.27.9		Deviating from PSP1	0 (as PSP1) / 255 (deviating)
12.27.10		global / operating mode depended	0 (OM depended) / 255 (global)
12.28.2	IMP Frequency isolated / global PSP2	Release delay	0.0 ... 600.0
12.28.3		Modulation	0 (PWM) / 1 (PFM)
12.28.4		Dead zone	0.0 ... 50.0 %
12.28.5		Amplify (pulse / % / pulse / per.)	0.01 ... 99.99
12.28.6		Pulse duration / period duration	0.1 ... 999.9 sec.
12.28.9		Deviating from PSP1	0 (as PSP1) / 255 (deviating)
12.28.10		global / operating mode depended	0 (OM depended) / 255 (global)
12.29.2	IMP Voltage SYN PSP2	Release delay	0.0 ... 600.0
12.29.3		Modulation	0 (PWM) / 1 (PFM)
12.29.4		Dead zone	0.0 ... 50.0 %
12.29.5		Amplify (pulse / % / pulse / per.)	0.01 ... 99.99
12.29.6		Pulse duration / period duration	0.1 ... 999.9 sec.
12.30.2	IMP Frequency SYN PSP2	Release delay	0.0 ... 600.0
12.30.3		Modulation	0 (PWM) / 1 (PFM)
12.30.4		Dead zone	0.0 ... 50.0 %
12.30.5		Amplify (pulse / % / pulse / per.)	0.01 ... 99.99
12.30.6		Pulse duration / period duration	0.1 ... 999.9 sec.
12.31.2	IMP Voltage Mains parallel PSP2	Release delay	0.0 ... 600.0
12.31.3		Modulation	0 (PWM) / 1 (PFM)
12.31.4		Dead zone	0.0 ... 50.0 %
12.31.5		Amplify (pulse / % / pulse / per.)	0.01 ... 99.99
12.31.6		Pulse duration / period duration	0.1 ... 999.9 sec.
12.32.2	IMP Frequency Mains parallel PSP2	Release delay	0.0 ... 600.0
12.32.3		Modulation	0 (PWM) / 1 (PFM)
12.32.4		Dead zone	0.0 ... 50.0 %
12.32.5		Amplify (pulse / % / pulse / per.)	0.01 ... 99.99
12.32.6		Pulse duration / period duration	0.1 ... 999.9 sec.

Synchronising Device SYR 2

Description

Parameter		Description	Setting range	Default
12.33.3	Electronic Potentiometer Voltage isolated / global PSP2	Ramp	0.1 ... 250.0 s	10.0 s
12.33.5		Swing	0.01 ... 10.00 V	5.00 V
12.33.6		Offset	0.00 ... 10.00 V	5.00 V
12.33.9		Deviating from PSP1	0 (as PSP1) / 255 (deviating)	0
12.33.10		global / operating mode depended	0 (OM depended) / 255 (global)	255
12.34.3	Electronic Potentiometer Frequency isolated / global PSP2	Ramp	0.1 ... 250.0 s	10,0 s
12.34.5		Swing	0.01 ... 10.00 V	5.00 V
12.34.6		Offset	0.00 ... 10.00 V	5.00 V
12.34.9		Deviating from PSP1	0 (as PSP1) / 255 (deviating)	0
12.34.10		global / operating mode depended	0 (OM depended) / 255 (global)	255
12.35.3	Electronic Potentiometer Voltage SYN PSP2	Ramp	0.1 ... 250.0 s	10,0 s
12.35.5		Swing	0.01 ... 10.00 V	5.00 V
12.35.6		Offset	0.00 ... 10.00 V	5.00 V
12.36.3	Electronic Potentiometer Frequency SYN PSP2	Ramp	0.1 ... 250.0 s	10,0 s
12.36.5		Swing	0.01 ... 10.00 V	5.00 V
12.36.6		Offset	0.00 ... 10.00 V	5.00 V
12.37.3	Electronic Potentiometer Voltage Mains parallel PSP2	Ramp	0.1 ... 250.0 s	10,0 s
12.37.5		Swing	0.01 ... 10.00 V	5.00 V
12.37.6		Offset	0.00 ... 10.00 V	5.00 V
12.38.3	Electronic Potentiometer Frequency Mains parallel PSP2	Ramp	0.1 ... 250.0 s	10,0 s
12.38.5		Swing	0.01 ... 10.00 V	5.00 V
12.38.6		Offset	0.00 ... 10.00 V	5.00 V
12.40.2	PID Voltage isolated / global PSP3	Delay time	0.0 ... 600.0	0.5 sec.
12.40.3		Ramp time	0.0 ... 600.0	0.0 sec.
12.40.4		Dead zone	0.0 ... 50.0 %	1.0 %
12.40.5		Amplification (Kp)	0.01 ... 99.99	0.10
12.40.6		Integration time (Tn)	0.0 ... 999.9 sec.	0.5 sec.
12.40.7		Derivative time (Tv)	0.0 ... 99.9 sec.	0.0 sec.
12.40.8		Reset time (T1)	0.0 ... 99.9 sec.	0.0 sec.
12.40.9		Deviating from PSP1	0 (as PSP1) / 255 (deviating)	0
12.40.10		global / operating mode depended	0 (OM depended) / 255 (global)	255
12.41.2	PID Frequency isolated / global PSP3	Delay time	0.0 ... 600.0	0.5 sec.
12.41.3		Ramp time	0.0 ... 600.0	0.0 sec.
12.41.4		Dead zone	0.0 ... 50.0 %	0.1 %
12.41.5		Amplification (Kp)	0.01 ... 99.99	0.10
12.41.6		Integration time (Tn)	0.0 ... 999.9 sec.	0.5 sec.
12.41.7		Derivative time (Tv)	0.0 ... 99.9 sec.	0.0 sec.
12.41.8		Reset time (T1)	0.0 ... 99.9 sec.	0.0 sec.
12.41.9		Deviating from PSP1	0 (as PSP1) / 255 (deviating)	0
12.41.10		global / operating mode depended	0 (OM depended) / 255 (global)	255
12.42.2	PID Voltage SYN PSP3	Delay time	0.0 ... 600.0	0.5 sec.
12.42.3		Ramp time	0.0 ... 600.0	0.0 sec.
12.42.4		Dead zone	0.0 ... 50.0 %	1.0 %
12.42.5		Amplification (Kp)	0.01 ... 99.99	0.10
12.42.6		Integration time (Tn)	0.0 ... 999.9 sec.	0.5 sec.
12.42.7		Derivative time (Tv)	0.0 ... 99.9 sec.	0.0 sec.
12.42.8		Reset time (T1)	0.0 ... 99.9 sec.	0.0 sec.
12.43.2	PID Frequency SYN PSP3	Delay time	0.0 ... 600.0	0.5 sec.
12.43.3		Ramp time	0.0 ... 600.0	0.0 sec.
12.43.4		Dead zone	0.0 ... 50.0 %	0.1 %
12.43.5		Amplification (Kp)	0.01 ... 99.99	0.10
12.43.6		Integration time (Tn)	0.0 ... 999.9 sec.	0.5 sec.
12.43.7		Derivative time (Tv)	0.0 ... 99.9 sec.	0.0 sec.
12.43.8		Reset time (T1)	0.0 ... 99.9 sec.	0.0 sec.
12.44.2	PID Voltage Mains parallel PSP3	Delay time	0.0 ... 600.0	0.5 sec.
12.44.3		Ramp time	0.0 ... 600.0	0.0 sec.
12.44.4		Dead zone	0.0 ... 50.0 %	1.0 %
12.44.5		Amplification (Kp)	0.01 ... 99.99	0.10
12.44.6		Integration time (Tn)	0.0 ... 999.9 sec.	0.5 sec.
12.44.7		Derivative time (Tv)	0.0 ... 99.9 sec.	0.0 sec.
12.44.8		Reset time (T1)	0.0 ... 99.9 sec.	0.0 sec.

Synchronising Device SYR 2

Description

Parameter	Description	Setting range	Default
12.45.2 12.45.3 12.45.4 12.45.5 12.45.6 12.45.7 12.45.8	PID Frequency Mains parallel PSP3	Delay time Ramp time Dead zone Amplification (Kp) Integration time (Tn) Derivative time (Tv) Reset time (T1)	0.0 ... 600.0 0.0 ... 600.0 0.0 ... 50.0 % 0.01 ... 99.99 0.0 ... 999.9 sec. 0.0 ... 99.9 sec. 0.0 ... 99.9 sec.
12.46.2 12.46.3 12.46.4 12.46.5 12.46.6 12.46.9 12.46.10	IMP Voltage isolated / global PSP3	Release delay Modulation Dead zone Amplify (pulse / % / pulse / per.) Pulse duration / period duration Deviating from PSP1 global / operating mode depended	0.0 ... 600.0 0 (PWM) / 1 (PFM) 0.0 ... 50.0 % 0.01 ... 99.99 0.1 ... 999.9 sec. 0 (as PSP1) / 255 (deviating) 0 (OM depended) / 255 (global)
12.47.2 12.47.3 12.47.4 12.47.5 12.47.6 12.47.9 12.47.10	IMP Frequency isolated / global PSP3	Release delay Modulation Dead zone Amplify (pulse / % / pulse / per.) Pulse duration / period duration Deviating from PSP1 global / operating mode depended	0.0 ... 600.0 0 (PWM) / 1 (PFM) 0.0 ... 50.0 % 0.01 ... 99.99 0.1 ... 999.9 sec. 0 (as PSP1) / 255 (deviating) 0 (OM depended) / 255 (global)
12.48.2 12.48.3 12.48.4 12.48.5 12.48.6	IMP Voltage SYN PSP3	Release delay Modulation Dead zone Amplify (pulse / % / pulse / per.) Pulse duration / period duration	0.0 ... 600.0 0 (PWM) / 1 (PFM) 0.0 ... 50.0 % 0.01 ... 99.99 0.1 ... 999.9 sec.
12.49.2 12.49.3 12.49.4 12.49.5 12.49.6	IMP Frequency SYN PSP3	Release delay Modulation Dead zone Amplify (pulse / % / pulse / per.) Pulse duration / period duration	0.0 ... 600.0 0 (PWM) / 1 (PFM) 0.0 ... 50.0 % 0.01 ... 99.99 0.1 ... 999.9 sec.
12.50.2 12.50.3 12.50.4 12.50.5 12.50.6	IMP Voltage Mains parallel PSP3	Release delay Modulation Dead zone Amplify (pulse / % / pulse / per.) Pulse duration / period duration	0.0 ... 600.0 0 (PWM) / 1 (PFM) 0.0 ... 50.0 % 0.01 ... 99.99 0.1 ... 999.9 sec.
12.51.2 12.51.3 12.51.4 12.51.5 12.51.6	IMP Frequency Mains parallel PSP3	Release delay Modulation Dead zone Amplify (pulse / % / pulse / per.) Pulse duration / period duration	0.0 ... 600.0 0 (PWM) / 1 (PFM) 0.0 ... 50.0 % 0.01 ... 99.99 0.1 ... 999.9 sec.
12.52.3 12.52.5 12.52.6 12.52.9 12.52.10	Electronic Potentiometer Voltage isolated / global PSP3	Ramp Swing Offset Deviating from PSP1 global / operating mode depended	0.1 ... 250.0 s 0.01 ... 10.00 V 0.00 ... 10.00 V 0 (as PSP1) / 255 (deviating) 0 (OM depended) / 255 (global)
12.53.3 12.53.5 12.53.6 12.53.9 12.53.10	Electronic Potentiometer Frequency isolated / global PSP3	Ramp Swing Offset Deviating from PSP1 global / operating mode depended	0.1 ... 250.0 s 0.01 ... 10.00 V 0.00 ... 10.00 V 0 (as PSP1) / 255 (deviating) 0 (OM depended) / 255 (global)
12.54.3 12.54.5 12.54.6	Electronic Potentiometer Voltage SYN PSP3	Ramp Swing Offset	0.1 ... 250.0 s 0.01 ... 10.00 V 0.00 ... 10.00 V
12.55.3 12.55.5 12.55.6	Electronic Potentiometer Frequency SYN PSP3	Ramp Swing Offset	0.1 ... 250.0 s 0.01 ... 10.00 V 0.00 ... 10.00 V
12.56.3 12.56.5 12.56.6	Electronic Potentiometer Voltage Mains parallel PSP3	Ramp Swing Offset	0.1 ... 250.0 s 0.01 ... 10.00 V 0.00 ... 10.00 V

Synchronising Device SYR 2

Description

Parameter		Description	Setting range	Default
12.57.3	Electronic Potentiometer Frequency Mains parallel PSP3	Ramp	0.1 ... 250.0 s	10.0 s
12.57.5		Swing	0.01 ... 10.00 V	5.00 V
12.57.6		Offset	0.00 ... 10.00 V	5.00 V
12.59.2	PID Voltage isolated / global PSP4	Delay time	0.0 ... 600.0	0.5 sec.
12.59.3		Ramp time	0.0 ... 600.0	0.0 sec.
12.59.4		Dead zone	0.0 ... 50.0 %	1.0 %
12.59.5		Amplification (Kp)	0.01 ... 99.99	0.10
12.59.6		Integration time (Tn)	0.0 ... 999.9 sec.	0.5 sec.
12.59.7		Derivative time (Tv)	0.0 ... 99.9 sec.	0.0 sec.
12.59.8		Reset time (T1)	0.0 ... 99.9 sec.	0.0 sec.
12.59.9		Deviating from PSP1	0 (as PSP1) / 255 (deviating)	0
12.59.10		global / operating mode depended	0 (OM depended) / 255 (global)	255
12.60.2	PID Frequency isolated / global PSP4	Delay time	0.0 ... 600.0	0.5 sec.
12.60.3		Ramp time	0.0 ... 600.0	0.0 sec.
12.60.4		Dead zone	0.0 ... 50.0 %	0.1 %
12.60.5		Amplification (Kp)	0.01 ... 99.99	0.10
12.60.6		Integration time (Tn)	0.0 ... 999.9 sec.	0.5 sec.
12.60.7		Derivative time (Tv)	0.0 ... 99.9 sec.	0.0 sec.
12.60.8		Reset time (T1)	0.0 ... 99.9 sec.	0.0 sec.
12.60.9		Deviating from PSP1	0 (as PSP1) / 255 (deviating)	0
12.60.10		global / operating mode depended	0 (OM depended) / 255 (global)	255
12.61.2	PID Voltage SYN PSP4	Delay time	0.0 ... 600.0	0.5 sec.
12.61.3		Ramp time	0.0 ... 600.0	0.0 sec.
12.61.4		Dead zone	0.0 ... 50.0 %	1.0 %
12.61.5		Amplification (Kp)	0.01 ... 99.99	0.10
12.61.6		Integration time (Tn)	0.0 ... 999.9 sec.	0.5 sec.
12.61.7		Derivative time (Tv)	0.0 ... 99.9 sec.	0.0 sec.
12.61.8		Reset time (T1)	0.0 ... 99.9 sec.	0.0 sec.
12.62.2	PID Frequency SYN PSP4	Delay time	0.0 ... 600.0	0.5 sec.
12.62.3		Ramp time	0.0 ... 600.0	0.0 sec.
12.62.4		Dead zone	0.0 ... 50.0 %	0.1 %
12.62.5		Amplification (Kp)	0.01 ... 99.99	0.10
12.62.6		Integration time (Tn)	0.0 ... 999.9 sec.	0.5 sec.
12.62.7		Derivative time (Tv)	0.0 ... 99.9 sec.	0.0 sec.
12.62.8		Reset time (T1)	0.0 ... 99.9 sec.	0.0 sec.
12.63.2	PID Voltage Mains parallel PSP4	Delay time	0.0 ... 600.0	0.5 sec.
12.63.3		Ramp time	0.0 ... 600.0	0.0 sec.
12.63.4		Dead zone	0.0 ... 50.0 %	1.0 %
12.63.5		Amplification (Kp)	0.01 ... 99.99	0.10
12.63.6		Integration time (Tn)	0.0 ... 999.9 sec.	0.5 sec.
12.63.7		Derivative time (Tv)	0.0 ... 99.9 sec.	0.0 sec.
12.63.8		Reset time (T1)	0.0 ... 99.9 sec.	0.0 sec.
12.64.2	PID Frequency Mains parallel PSP4	Delay time	0.0 ... 600.0	0.5 sec.
12.64.3		Ramp time	0.0 ... 600.0	0.0 sec.
12.64.4		Dead zone	0.0 ... 50.0 %	0.1 %
12.64.5		Amplification (Kp)	0.01 ... 99.99	0.10
12.64.6		Integration time (Tn)	0.0 ... 999.9 sec.	0.5 sec.
12.64.7		Derivative time (Tv)	0.0 ... 99.9 sec.	0.0 sec.
12.64.8		Reset time (T1)	0.0 ... 99.9 sec.	0.0 sec.
12.65.2	IMP Voltage Mains parallel PSP4	Release delay	0.0 ... 600.0	0.5 sec.
12.65.3		Modulation	0 (PWM) / 1 (PFM)	1
12.65.4		Dead zone	0.0 ... 50.0 %	1.0 %
12.65.5		Amplify (pulse / % / pulse / per.)	0.01 ... 99.99	0.5 sec.
12.65.6		Pulse duration / period duration	0.1 ... 999.9 sec.	0.1 sec.
12.65.9		Deviating from PSP1	0 (as PSP1) / 255 (deviating)	0
12.65.10		global / operating mode depended	0 (OM depended) / 255 (global)	255
12.66.2	IMP Frequency Mains parallel PSP4	Release delay	0.0 ... 600.0	0.5 sec.
12.66.3		Modulation	0 (PWM) / 1 (PFM)	1
12.66.4		Dead zone	0.0 ... 50.0 %	0.1 %
12.66.5		Amplify (pulse / % / pulse / per.)	0.01 ... 99.99	0.5 sec.
12.66.6		Pulse duration / period duration	0.1 ... 999.9 sec.	0.1 sec.
12.66.9		Deviating from PSP1	0 (as PSP1) / 255 (deviating)	0
12.66.10		global / operating mode depended	0 (OM depended) / 255 (global)	255

Synchronising Device SYR 2

Description

Parameter		Description	Setting range	Default
12.67.2	IMP Voltage SYN PSP4	Release delay	0.0 ... 600.0	0.5 sec.
12.67.3		Modulation	0 (PWM) / 1 (PFM)	1
12.67.4		Dead zone	0.0 ... 50.0 %	1.0 %
12.67.5		Amplify (pulse / % / pulse / per.)	0.01 ... 99.99	0.5 sec.
12.67.6		Pulse duration / period duration	0.1 ... 999.9 sec	0.1 sec.
12.68.2	IMP Frequency SYN PSP4	Release delay	0.0 ... 600.0	0.5 sec.
12.68.3		Modulation	0 (PWM) / 1 (PFM)	1
12.68.4		Dead zone	0.0 ... 50.0 %	0.1 %
12.68.5		Amplify (pulse / % / pulse / per.)	0.01 ... 99.99	0.5 sec.
12.68.6		Pulse duration / period duration	0.1 ... 999.9 sec	0.1 sec.
12.69.2	IMP Voltage Mains parallel PSP4	Release delay	0.0 ... 600.0	0.5 sec.
12.69.3		Modulation	0 (PWM) / 1 (PFM)	1
12.69.4		Dead zone	0.0 ... 50.0 %	1.0 %
12.69.5		Amplify (pulse / % / pulse / per.)	0.01 ... 99.99	0.5 sec.
12.69.6		Pulse duration / period duration	0.1 ... 999.9 sec	0.1 sec.
12.70.2	IMP Frequency Mains parallel PSP4	Release delay	0.0 ... 600.0	0.5 sec.
12.70.3		Modulation	0 (PWM) / 1 (PFM)	1
12.70.4		Dead zone	0.0 ... 50.0 %	0.1 %
12.70.5		Amplify (pulse / % / pulse / per.)	0.01 ... 99.99	0.5 sec.
12.70.6		Pulse duration / period duration	0.1 ... 999.9 sec	0.1 sec.
12.71.3	Electronic Potentiometer Voltage isolated / global PSP4	Ramp	0.1 ... 250.0 s	10.0 s
12.71.5		Swing	0.01 ... 10.00 V	5.00 V
12.71.6		Offset	0.00 ... 10.00 V	5.00 V
12.71.9		Deviating from PSP1	0 (as PSP1) / 255 (deviating)	0
12.71.10		global / operating mode depended	0 (OM depended) / 255 (global)	255
12.72.3	Electronic Potentiometer Frequency isolated / global PSP4	Ramp	0.1 ... 250.0 s	10.0 s
12.72.5		Swing	0.01 ... 10.00 V	5.00 V
12.72.6		Offset	0.00 ... 10.00 V	5.00 V
12.72.9		Deviating from PSP1	0 (as PSP1) / 255 (deviating)	0
12.72.10		global / operating mode depended	0 (OM depended) / 255 (global)	255
12.73.3	Electronic Potentiometer Voltage SYN PSP4	Ramp	0.1 ... 250.0 s	10.0 s
12.73.5		Swing	0.01 ... 10.00 V	5.00 V
12.73.6		Offset	0.00 ... 10.00 V	5.00 V
12.74.3	Electronic Potentiometer Frequency SYN PSP4	Ramp	0.1 ... 250.0 s	10.0 s
12.74.5		Swing	0.01 ... 10.00 V	5.00 V
12.74.6		Offset	0.00 ... 10.00 V	5.00 V
12.75.3	Electronic Potentiometer Voltage Mains parallel PSP4	Ramp	0.1 ... 250.0 s	10.0 s
12.75.5		Swing	0.01 ... 10.00 V	5.00 V
12.75.6		Offset	0.00 ... 10.00 V	5.00 V
12.76.3	Electronic Potentiometer Frequency Mains parallel PSP4	Ramp	0.1 ... 250.0 s	10.0 s
12.76.5		Swing	0.01 ... 10.00 V	5.00 V
12.76.6		Offset	0.00 ... 10.00 V	5.00 V

Subject to technical modifications!

Hanseatic Power Solutions GmbH
Oststraße 67
22844 Norderstedt

Telefon +49 (0)40 5303479-0
Telefax +49 (0)40 5303479-90
Internet www.hps-power.com